

Certificate of Accreditation

Amendment 1

Name of product:	Masterwall Reinforced Polystyrene Wall Cladding System (X-Series and M-Series)
Product description:	Wall cladding system
Description of the purpose and use of the building product:	For use in Class 1 and associated Class 10 buildings
Regulation/s in relation to which the building product is accredited:	<p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and accredited the system as complying with;</p> <p>Performance Requirements P2.1.1 and P2.2.2 of the National Construction Code Series, Volume Two of the Building Code of Australia 2019, as adopted by the Building Regulations as in force from time to time, to the extent that those clauses refer to structural stability, resistance to wind action and rainwater action, and weatherproofing of the system, subject to the following conditions:</p>
Conditions to which the accreditation is subject:	<ol style="list-style-type: none">1. The Masterwall Reinforced Polystyrene Wall Cladding System X-Series must be installed in accordance with the 'X-Series Direct-to-frame System Manual (February 2023)'2. The Masterwall Reinforced Polystyrene Wall Cladding System M-Series must be installed in accordance with the 'M-Series System Manual (February 2023)'3. The Masterwall Reinforced Polystyrene Wall Cladding System (X-Series and M-Series) must not be installed on wall heights greater than 9 metres4. Each polystyrene panel used as part of the Masterwall Reinforced Polystyrene Wall Cladding System (X-Series and M-Series) must be stamped, or otherwise marked, with a legible, permanent label stating that the system must incorporate a vapour permeable sarking membrane between the polystyrene panels and the frame.

Notes:

This BRAC Certificate does not accredit the product for use in bushfire prone areas.

The accreditation of this product does not apply to any other provisions of the National Construction Code Series.

Building

Regulations Advisory Committee

The name, address and Australian business number of the holder of the accreditation: Masterwall
18-20 Cyber Loop
Dandenong South VIC 3175
ABN: 23 616 425 211

Certificate number: V09/01-A1

Date of issue: 23/03/2023

Refer to the Historical Details page of this Certificate.
This Certificate is only valid when reproduced in its entirety.

Date of expiry of accreditation: 23/03/2026

Signature:



**Commissioner Yvonne von Hartel AM
Chair, Building Regulations Advisory Committee**

Practitioner guidance on how to use a Certificate of accreditation

Practitioners are reminded to consider any limitations noted in this Certificate and whether the performance of the product has been tested for all aspects of the performance that it is expected to achieve in the application it is being applied to.

Building

Regulations Advisory Committee

Historical Details

Certificate number:	Description:	From:	To:
V09/01	Accreditation granted	23 December 2009	-
V09/01-A1	Amendment to Certificate details: <ul style="list-style-type: none">• Reaccreditation granted for a period of 3 years• New certificate number issued• Applies to both the X-Series and M-Series only• Conditions updated to reference the February 2023 product manuals• Inclusion of a note that this BRAC Certificate does not accredit the product for use in bushfire prone areas• Accreditation holder change of address	23 March 2023	23 March 2026