

AUDIT

8: Backflow Prevention (Medium and High Risk Only)

Checklist



LEVEL 1
☐ Have individual hazard(s) been identified?
☐ Is the device(s) suitable for the degree of hazard?
☐ Have approved devices been installed?
☐ Does the individual/zone/containment protection comply?
☐ Does the device installation comply?
Is the device accessible for servicing?
☐ Has the device been commissioned by an approved practitioner?
Is the practitioner accredited in Backflow Prevention?
LEVEL 2
Does the device have the correct support?
Where applicable do the tundish and drain lines comply?
☐ Does the installation have approved isolation valves/strainers?
Have the approved clearances for testing purposes been met?
Has the device been included in a commissioning, testing and maintenance program?
$\hfill \square$ Where required, has a modification application been submitted and approved?
☐ Have the manufacturer's installation instructions been adhered to?
☐ Has the class of plumbing been indicated on the compliance certificate?
☐ Where relevant, has documentation for a performance solution been provided?

REFERENCES

Does the installation comply with the minimum industry standards:

 AS/NZS 2845. 2: Water supply – Backflow prevention devices Part 2: Air gaps and break tanks



Victorian Building Authority

- AS/NZS 3500.1: Plumbing and drainage Part 1 Water services Section 4,
- AS/NZS 3500.5: Plumbing and drainage / Housing installations Section 2
- The requirements of Section B of the Plumbing Code of Australia (PCA)
- The Plumbing Regulations 2018
- The relevant manufacturer's installation instructions

NOTES

The standards and audit items listed on this checklist are intended as a guide only and are not an exhaustive list.

Other standards may be applicable to the installation and should be referenced as required, additionally Audit items may alter dependent on actual work conducted and final installation.

Practitioners are advised to check that they are using the most current edition of the prescribed standards at the time of installation.

