

Building

Regulations Advisory Committee

Certificate of Accreditation

Amendment 2

| | |
|--|---|
| Name of product: | Ultratex Grey Board EIFS Wall Cladding System |
| Product description: | Wall cladding system |
| Description of the purpose and use of the building product: | Suitable for use in Class 1 and Class 10 buildings |
| Regulation/s in relation to which the building product is accredited: | <p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and accredited the product as complying with;</p> <p>Performance Requirement P2.1.1 of Volume Two of the National Construction Code Series and P2.2.2 of Volume Two of the National Construction Code Series</p> <p>Building Code of Australia Class 1 and 10 buildings, as adopted by the Building Regulations 2018, as these clauses apply within the state of Victoria to wall cladding, subject to the following conditions:</p> |
| Conditions to which the accreditation is subject: | <ol style="list-style-type: none">1. This accreditation applies to the Ultratex Grey Board EIFS direct fix and cavity wall cladding systems only2. This product must be installed on Class 1 and 10 buildings only3. This product must be installed in wind classifications N1 to N4 only4. This product must be installed in accordance with the Ultratex Grey Board EIFS Wall Cladding Systems Installation & Technical Manual version 2D dated 02 December 20145. This product must be installed on timber framework only with minimum 90mm x 35mm studs at a spacing of 600mm and fastener spacing of 300mm6. This product must be installed with breathable sarking7. Fasteners must be installed through polystyrene panels with a minimum of 25mm depth into timber framework8. All fixtures and features attached to the wall must be secured into the wall framing9. This product must be installed a minimum of 100mm from any finished external ground surface10. Render must be applied strictly in accordance with manufacturers installation requirements <p>This accreditation does not apply to any other provisions of the National Construction Code Series.</p> |

Building

Regulations Advisory Committee

The name, address and Australian business number of the holder of the accreditation: Ultratex Wall Cladding & Coating P/L
15/A Malcolm Crt
Kealba VIC 3021
ABN 50119993412

Certificate number: V15/01-A2

Date of issue: 30/11/2021

Refer to the Historical Details page of this Certificate.
This Certificate is only valid when reproduced in its entirety.

Date of expiry of accreditation: 30/11/2024

Signature:



.....
Commissioner Yvonne von Hartel AM
Chair, Building Regulations Advisory Committee

Practitioner guidance on how to use a Certificate of accreditation

Practitioners are reminded to consider any limitations noted in this Certificate and whether the performance of the product has been tested for all aspects of the performance that it is expected to achieve in the application it is being applied to.

Building

Regulations Advisory Committee

Historical Details

| Certificate number: | Description: | From: | To: |
|---------------------|--|------------------|------------------|
| V15/01 | Accreditation granted. | 12 March 2015 | - |
| V15/01-A1 | Amendment to Certificate: <ul style="list-style-type: none">- Reissued on BRAC letterhead and signed by Chair- Updated references to Regulations | 01 July 2019 | - |
| V15/01-A2 | Amendment to Certificate: <ul style="list-style-type: none">- Accreditation granted for a period of 3 years- Condition 9 amended to include the word "finished" | 30 November 2021 | 30 November 2024 |