

# Building

## Regulations Advisory Committee

# Certificate of Accreditation

## Amendment 1

<b>Name of product:</b>	Tyco automatic fire alarm monitoring system, including the CENTAUR Alarm Signalling Equipment
<b>Product description:</b>	Fire alarm monitoring system and alarm Signalling Equipment
<b>Description of the purpose and use of the building product:</b>	Suitable for use in connecting installations in buildings to a fire station or fire station dispatch centre
<b>Regulation/s in relation to which the building product is accredited:</b>	<p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and accredited the product as complying with;</p> <p>Sections C&amp;E of Volume One of the Building Code of Australia, as adopted by the Building Regulations as in force from time to time, subject to the following conditions:</p>
<b>Conditions to which the accreditation is subject:</b>	<ol style="list-style-type: none"><li>1. The ADT, Centaur II, CAT-M1/4G and Dual 4G Series alarm signalling equipment complies with the relevant requirements of the Australian Standard AS4428.6:2018, 'Fire detection, warning, control and intercom systems - Control and indicating equipment – Alarm signalling equipment</li><li>2. The equipment is installed in accordance with the Centaur II Alarm Signalling Equipment Installation Guide (24 February 2010)</li></ol>
<b>The name, address and Australian business number of the holder of the accreditation:</b>	<p>ADT Fire Monitoring Lvl.3. 37 Dalmore Drive SCORESBY VIC 3179 ABN: 93 07 68 36 416</p>

**Certificate number:** V00/03-A1

**Date of issue:** 04/08/2022

Refer to the Historical Details page of this Certificate.  
This Certificate is only valid when reproduced in its entirety.

# Building

## Regulations Advisory Committee

Date of expiry of accreditation: 04/08/2025

Signature:



**Commissioner Sam Torre**  
Acting Chair, Building Regulations Advisory Committee

### Practitioner guidance on how to use a Certificate of accreditation

Practitioners are reminded to consider any limitations noted in this Certificate and whether the performance of the product has been tested for all aspects of the performance that it is expected to achieve in the application it is being applied to.

## Historical Details

Certificate number:	Description:	From:	To:
V00/03	Accreditation granted	10 October 2000	-
V00/03-A1	Amendment to Certificate details: <ul style="list-style-type: none"><li>• Reaccreditation granted for a period of 3 years</li><li>• New certificate number issued</li><li>• Alignment with the requirements of AS4428.6:2018</li><li>• Updated reference to product manual</li><li>• Change of address of holder of accreditation</li></ul>	04 August 2022	04 August 2025