

AUDIT

92: Natural Gas Type A Servicing, Including 93: LPG Type A, 94: Other Types of Gas

Checklist

Performance and Compliance Check Level 1 and Level 2 Faults

LEVEL 1

- Are the materials used fit for their intended purpose and where required appropriately authorised?
- Following servicing is the installation of the appliance safe?
- Has the installation / appliance been installed correctly?
- If applicable is the new consumer piping gas tight?
- If applicable is the existing consumer piping within the allowable pressure drop?
- Have the appliance fluing requirements been met?
- Have the appliance ventilation requirements been met?
- Have all the required clearances and specific appliance installation requirements been met?
- Has the appliance been serviced to manufacturer's specifications / materials?
- Has the installation been commissioned?

LEVEL 2

- Have access provisions to the appliance been provided?
- Have any components been replaced that require a compliance certificate to be lodged for the work or that are over the prescribed combined amount?
- Where required, has an as exemption been submitted and approved for design alterations?
- Have the manufacturer's installation instructions been adhered to?
- Has the class of plumbing been indicated on the compliance certificate if required?



REFERENCES

Does the installation comply with the minimum industry standards:

- AS/NZS 5601: parts 1 & 2: Gas installations
- AS 4575: Gas appliances – Quality of servicing
- The relevant manufacturer's installation instructions

NOTES

The standards and audit items listed on this checklist are intended as a guide only and are not an exhaustive list.

Other standards may be applicable to the installation and should be referenced as required, additionally Audit items may alter dependent on actual work conducted and final installation.

Practitioners are advised to check that they are using the most current edition of the prescribed standards at the time of installation.