

Certificate of Accreditation

Amendment 1

Name of product:	Geelong Polystyrene Cladding System
Product description:	Wall cladding system
Description of the purpose and use of the building product:	Suitable for use on low rise residential Class 1 and associated Class 10 buildings
Regulation/s in relation to which the building product is accredited:	<p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and accredited the product as complying with:</p> <p>Performance Requirement P2.1.1, P2.2.2 and P2.2.3 of the National Construction Code Series, Volume Two, Building Code of Australia, Class 1 and Class 10 buildings as adopted by the Building Interim Regulations 2017, to the extent that those clauses refer to the structural performance of external walls, resistance to wind action and rainwater action, and weatherproofing, and damp-proofing, of external wall systems, subject to the following conditions:</p>
Conditions to which the accreditation is subject:	<ol style="list-style-type: none">1. The accreditation is limited to Class 1 and Class 10 buildings in wind classes N1 to N3, with geometric limits set out in clause 1.2, of AS 4055 - 2012 Wind Loads for housing, as amended from time to time.2. Installation must be in accordance with the Geelong Polystyrene Cladding System for Low-Rise Residential Buildings Technical Manual June 2017 Edition.3. The system must be installed on timber framework complying with AS 1684 Residential timber - framed construction, as amended from time to time, with studs at a maximum spacing of 600mm centre to centre.4. The sarking to be installed as part of the system must be breathable sarking.5. Panel to timber batten fasteners must be installed with a minimum embedment depth of 25mm.6. All fixtures and features attached to the wall must be secured into wall framing.7. The system must be installed at a minimum of 100mm from any finished external ground surface.8. Render must be applied strictly in accordance with the manufacturer's installation requirements.

Building

Regulations Advisory Committee

The name, address and Australian business number of the holder of the accreditation: Geelong Polystyrene Products P/L
4 Lewalan Street
GROVEDALE VIC 3216
ABN 59118 022 236

Certificate number: V17/01-A1

Date of issue: 02/12/2021

Refer to the Historical Details page of this Certificate.
This Certificate is only valid when reproduced in its entirety.

Date of expiry of accreditation: 02/12/2024



.....

Commissioner Yvonne von Hartel AM
Chair, Building Regulations Advisory Committee

Practitioner guidance on how to use a Certificate of accreditation

Practitioners are reminded to consider any limitations noted in this Certificate and whether the performance of the product has been tested for all aspects of the performance that it is expected to achieve in the application it is being applied to.

Building

Regulations Advisory Committee

Historical Details

Certificate number:	Description:	From:	To:
V17/01	Accreditation granted.	16 August 2017	-
V17/01-A1	Amendment to Certificate: <ul style="list-style-type: none">- Accreditation granted for a period of 3 years- Condition 7 amended to include the word "finished"- All conditions listed as numbers rather than roman numerals	02 December 2021	02 December 2024