

Register of Accredited Building Products

Accredited by the Building Regulations Advisory Committee

The following is the register of building products including construction methods, designs, components, or systems connected with building work and accredited by the Building Regulations Advisory Committee under the *Building Regulations 2018 – Building Product Accreditation (Section 251.(2))*. The register is updated whenever any changes are made to a Certificate of Accreditation.

*** Please note as at May 2022: Not all current Accredited Building Products listed in this register have had 3-year expiry dates applied. Applying 3-year expiry dates to Certificates of Accreditation is a planned program of work that the Building Regulations Advisory Committee is currently undertaking in accordance with the *Building and Environment Protection Legislation Amendment Act 2020 (Vic)*. All current Certificates of Accreditations that appear in this register are valid, regardless of whether they are yet to have a 3-year expiry date applied.**

Certificates of Accreditation that have been revoked are not valid and have been highlighted in grey at the end of this register.

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation
Tyco automatic fire alarm monitoring system, including the CENTAUR Alarm Signalling Equipment	Fire alarm monitoring system and alarm Signalling Equipment	Suitable for use in connecting installations in buildings to a fire station or fire station dispatch centre	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the 1993 has examined the application and determined that Tyco automatic fire alarm monitoring systems complies with the relevant Performance Requirements of: Sections C&E of Volume One of the Building Code of Australia 1996, as adopted by the Building Regulations 1994	As those Clauses apply to fire monitoring systems and subject to the following conditions: (i) The alternative facility which is to be used in the event of the loss of the permanent link must be a telephone line that is automatically connected to the Public Switched Telephone Network. (ii) The system an equipment complies with the attached data sheet 'Tyco Fire Monitoring - Centaur Alarm Signalling Equipment - 9906/ 1'. (iii) The service provider (Tyco) is to provide a report to the Building Regulations Advisory Committee within seven working days in the event of the network failing to achieve the availability required by clause 2.3 (f) of AS 1670.3. The report shall include details of - (a) the period of non-compliance; and (b) the reason for the network non-compliance; and (c) a description of the actions taken to rectify the network.	Tyco Fire Monitoring Tyco Australia Pty Ltd 1 / 613 Victoria Street ABBOTTSFORD VIC 3067	V00/03	10/10/2000				
Enzie Spiral Stair (H-S Model 1300/12, 1500/14, 1750/16 and 1880/16)	Spiral stairs (H-S Model)	Suitable for use in a Class 1 buildings, and as private stairs in sole occupancy units of Class 2 and 3 buildings and a Class 4 part of a building	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and determined that the Enzie Spiral Stair (H-S Model) complies with the requirements where appropriate to stairways of Clauses DP 2 (c) and DP 3 of Volume One and Clauses P 2.5.1 (b) and P2.5.2 of Volume Two of the Building Code of Australia as adopted by the Building Regulations 2018, subject to the following conditions:	The product must be installed in accordance with the details provided in the four data sheets for the H-S model: <ul style="list-style-type: none"> • H-S Model 1300/12 Data Sheet, dated 30/03/2022 • H-S Model 1500/14 Data Sheet, dated 30/03/2022 • H-S Model 1750/16 Data Sheet, dated 30/03/2022 • H-S Model 1880/16 Data Sheet, dated 30/03/2022 	Enzie Stairs Pty Ltd 8 Vimy Street RESERVOIR VIC 3073	V00/04-A3	03/05/2022	03/05/2025		03/05/2022 <ul style="list-style-type: none"> • Accreditation granted for a period of 3-years • New certificate number issued • Accreditation for the H-S Series Model only • Date references added to data sheets • Accreditation holders address updated 	

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation
Stramit Uniguard Fire-Resisting Wall System	Fire-resisting External wall system	Suitable for use as an external wall system for single storey Class 7b and 8 buildings of Type C construction, as defined in the Building Code of Australia, located within 3m of a fire source feature.	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and accredited the product as complying with; Performance Requirement CP1 and CP2(a)(iii) of Volume One of the Building Code of Australia, as adopted by the Building Regulations 2018	When installed in accordance with the conditions for use details provided in the following attached documents: - Product Technical Manual, Stramit Uniguard Fire-Resisting Wall System, dated September 2009 - Warrington Fire Australia Performance Report No. 2275300-RPT01, version 6, dated 03 October 2019 - Drawing No. TL049, Revision B, dated 7 June 2005	Stramit Building Products Site A, 33-83 Quarry Road ERSKIN PARK NSW 2759	V05/01-A1	25/03/2022	25/03/2025		25/03/2022 • Accreditation granted for a period of 3-years • Reference to Building Regulations updated • Reference to product manual updated • Reference to product test report updated based on current version of NCC (2019) • Change of address of holder of accreditation	
TEK stump 75mm and 85mm square concrete stump	75mm and 85mm square concrete stump	For use in re blocking	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and determined that TEK stump 75mm and 85mm square concrete stump complies with Performance Requirement: P 2.1 of Volume Two of the Building Code of Australia as adopted by the Building Regulations 2006,	As that clause applies to the use of the stump in reblocking, provided each installation is in accordance with the conditions for use and identification details in the three (1) data sheet attached and subject to the following conditions: (i) the stumps may only be used for single storey construction; and (ii) The roof load must not exceed 5 metres; and (iii) The uniformly distributed floor live load must not exceed 1.5kPa; and (iv) The allowable bearing pressure of the soil must not be less than 75 kPa.	Stump Systems 31 Edinburgh Road Lilydale Victoria 3140	V06/02	19/07/2006				
HIA Alternative Solution - Class 1 and Class 10 buildings - Wet Area Requirements for a timber floor adjacent to a bath or enclosed shower with a preformed shower base.	HIA Alternative Solution provides alternative wet area requirements for a timber floor adjacent to a bath or enclosed shower with a preformed shower base in Class 1 and 10 buildings. All other wet areas including a shower, bath, basin, etc. must comply with the wet area	For use in Class 1 and Class 10 buildings for a timber floor adjacent to a bath or enclosed shower with a preformed shower base.	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and accredited the HIA Alternative Solution - Class 1 and Class 10 buildings - Wet Area Requirements for a timber floor adjacent to a bath or enclosed shower with a preformed shower base as complying with: Performance Requirement P2.4.1 of the National Construction Code Series, Volume Two, Building Code of Australia, Class 1 and Class 10 buildings (BCA Volume Two) as adopted by the Building Regulations 2018,	1. This Alternative Solution provides alternative wet area requirements for a timber floor adjacent to a bath or enclosed shower with a preformed shower base in Class 1 and 10 buildings. All other wet areas including a shower, bath, basin, etc. must comply with the wet area requirements of Part 3.8.1 of the Building Code of Australia 2005 Volume Two. 2. A preformed shower base must be installed in accordance with the manufacturer's instructions. 3. The use of this Alternative Solution is conditional on the builder notifying the owner that they must ensure that the grout and caulking of the shower enclosure and walls is maintained to prevent penetration of water. 4. This alternative solution does not apply to a timber floor adjacent to a shower located above a bath. 5. Timber floors, including particleboard, plywood and other timber-based flooring material adjacent to a bath or enclosed shower with a preformed shower base must be <i>water resistant</i> . 6. Finished wall and floor tile junctions must not be grouted but sealed with a flexible sealant to create a flexible movement joint 7. Wall tiles must be finished over the edge of the floor tiles.	Housing Industry Association 70 Jolimont Street JOLIMONT VIC 3002	V07/03-A2	12/01/2022	12/01/2025		12/01/2022 • Accreditation granted for a period of 3-years • An amendment to condition 3 to incorporate the requirement for the builder to notify the owner of maintenance requirements	

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation
	requirements of Part 3.8.1 of the Building Code of Australia 2005 Volume Two		when installed with the following conditions:	<p>8. The following materials when used in conjunction with <i>water resistant</i> surface materials are deemed to be water resistant:</p> <ul style="list-style-type: none"> (i) Compressed fibre cement sheeting manufactured in accordance with AS/NZS 2908.2 - 2000. (ii) Fibre cement sheeting manufactured in accordance with AS/NZS 2908.2 - 2000 and supported on a structural floor. (iii) Flooring grade particleboard flooring. (iv) Structural plywood manufactured in accordance with AS/NZS 2269 - 2004 and installed in accordance with AS 1684.2 - 1999, AS 1084.3 - 1999 or AS 1684.4 - 1999. <p>9. The following surface materials, when used in conjunction with a <i>water-resistant</i> substrate are deemed to be <i>water resistant</i>:</p> <ul style="list-style-type: none"> (i) Tiles. (ii) Water resistant flexible sheet flooring material with sealed joints. Sheet vinyl or linoleum would be considered water resistant flexible sheet flooring material <p>10. Definitions:</p> <p>Enclosed shower means a shower area enclosed to a height of 1.8 m above the shower floor area by water resistant walls, glazed panels or doors, metal framed shower screens, that will control the spread of water to within the enclosure.</p> <p>Shower base means a preformed, prefinished vessel installed as the finished floor of a shower compartment, and which is provided with connection to a sanitary drainage system. Shower bases are commonly made of plastics, composite materials, vitreous enamelled pressed steel, or stainless steel.</p> <p>Vessel means an open, preformed, pre-finished concave receptacle capable of holding water for residential use, usually for the purpose of washing, including a basin, sink, bath, laundry tub and the like.</p> <p>Water resistant means a system or material that will restrict water migration. Wet area means an area within a building supplied with water from a water supply system and includes bathrooms, showers, laundries, sanitary compartments and the like.</p> <p>This accreditation does not apply to any other provisions of the National Construction Code Series.</p>							

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation																				
Masterwall Reinforced Polystyrene Wall Cladding System	Wall cladding system	For use in Class 1 and associated Class 10 buildings	<p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the <i>Building Act 1993</i> has examined the application and determined that the Masterwall Reinforced Polystyrene Wall Cladding System complies with the following Performance Requirements:</p> <p>P2.1 and P2.2.2 of Volume Two of the Building Code of Australia 2009 as adopted by the Building Regulations 2006</p>	<p>To the extent that those clauses refer to the structural stability, resistance to wind action and rainwater action, and weatherproofing of the system, subject to the following conditions:</p> <p>(i) The system must be installed on framing with stud spacing at a maximum of 600 mm centres and in accordance with the MasterWall Product Specification and Installation Manual 2009 except that it must not be used in areas with a wind classification of more than N5 under AS 4055 and in areas with a wind classification of N4 or N5 the maximum vertical fastener spacing (mm) is as follows—</p> <table border="1" data-bbox="893 590 1516 936"> <thead> <tr> <th rowspan="2">Stud spacing (mm)</th> <th rowspan="2">Location (mm)</th> <th colspan="2">Wind classification to AS 4055</th> </tr> <tr> <th>N4</th> <th>N5</th> </tr> </thead> <tbody> <tr> <td rowspan="2">450</td> <td>Within 1200 of building edge</td> <td>300</td> <td>200</td> </tr> <tr> <td>Elsewhere</td> <td>In accordance with Manual</td> <td>400</td> </tr> <tr> <td rowspan="2">600</td> <td>Within 1200 of building edge</td> <td>200</td> <td>Not suitable</td> </tr> <tr> <td>Elsewhere</td> <td>400</td> <td>300</td> </tr> </tbody> </table> <p>(ii) The system must not be installed more than 9m above ground level.</p> <p>(iii) Each polystyrene panel used as part of the system must be stamped, or otherwise marked, with a legible, permanent label stating that the system must incorporate a vapour permeable sarking membrane between the polystyrene panels and the frame.</p>	Stud spacing (mm)	Location (mm)	Wind classification to AS 4055		N4	N5	450	Within 1200 of building edge	300	200	Elsewhere	In accordance with Manual	400	600	Within 1200 of building edge	200	Not suitable	Elsewhere	400	300	Practica MMC Pty Ltd 9-11 Wren Road MOORABBIN VIC 3189	V09/01	23/12/2009				
Stud spacing (mm)	Location (mm)	Wind classification to AS 4055																													
		N4	N5																												
450	Within 1200 of building edge	300	200																												
	Elsewhere	In accordance with Manual	400																												
600	Within 1200 of building edge	200	Not suitable																												
	Elsewhere	400	300																												
Wildfire Safety Bunker	Private bushfire shelter	For use by up to six people for a maximum period of one hour as a class 10c building associated with a Class 1 building	<p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the <i>Building Act 1993</i> has examined the application and accredited the Wildfire Safety Bunker six person private bushfire shelter as complying with:</p> <p>Performance Requirements P2.1.1 and P2.7.6 of the National Construction Code Series, Volume Two, Building Code of Australia, Class 1 and Class 10 buildings as adopted by the building regulations as in force from time to time, subject to the following conditions:</p>	<p>I. The Wildfire Safety Bunker six person private bushfire shelter is limited to construction on sites that have been assessed as BAL-FZ or a lower BAL when assessed in accordance AS3959- 2018.</p> <p>II. The Wildfire Safety Bunker six person private bushfire shelter is installed, operated and maintained in accordance with Wildfire Safety Bunker instruction manual dated 18 January 2010.</p> <p>This accreditation does not apply to any other provisions of the National Construction Code Series.</p>	Wildfire Safety Bunkers Pty Ltd PO Box 1225 MORNINGTON VIC 3931	V10/01-A3	26/02/2020			26/02/2020 •To update reference to AS3959-2018																					
Insulcon Panel External Cladding System	External panel cladding system	Suitable for use as a wall cladding system on Class 2 to 9 buildings of Type 'C' construction only and Class 1 and 10 buildings.	Accredited against Volume One BP1.1, BP1.2 and Volume Two P2.1, P2.2.2 of the <i>Building Code of Australia 2010</i> as adopted by the <i>Building Regulations 2006</i> , to the extent that those Clauses refer to the structural stability, resistance to wind action, rainwater	<p>1. The system must be installed on framing with stud spacing at a minimum of 600mm centres and in accordance with the Insulcon Panels Installation Manual issued June 2008 (revised January 2011) except that it must not be used in areas with a wind classification of more than N5 under AS 4055 and the maximum vertical fastener spacing (mm) must be as follows –</p> <table border="1" data-bbox="914 1892 1516 1990"> <thead> <tr> <th rowspan="2">Stud spacing (mm)</th> <th rowspan="2">Location (mm)</th> <th colspan="5">Wind classification to AS 4055</th> </tr> <tr> <th>N1</th> <th>N2</th> <th>N3</th> <th>N4</th> <th>N5</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Stud spacing (mm)	Location (mm)	Wind classification to AS 4055					N1	N2	N3	N4	N5								Insulcon Pty Ltd 28 Mickle Street DANDENONG VIC 3175	V11/02-A1	01/07/2019			01/07/2019 •Certificate reissued on BRAC letterhead and signed by Chair •Certificate updated with		
Stud spacing (mm)	Location (mm)	Wind classification to AS 4055																													
		N1	N2	N3	N4	N5																									

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation																																			
			action and waterproofing of the system, subject to the following conditions:	<table border="1" data-bbox="914 281 1516 730"> <tr> <td rowspan="2">450</td> <td>Within 1200 of building edge</td> <td>300</td> <td>400</td> <td>300</td> <td>200</td> <td>150</td> </tr> <tr> <td>Elsewhere</td> <td>600</td> <td>600</td> <td>600</td> <td>400</td> <td>250</td> </tr> <tr> <td rowspan="2">600</td> <td>Within 1200 of building edge</td> <td>400</td> <td>400</td> <td>250</td> <td>NS</td> <td>NS</td> </tr> <tr> <td>Elsewhere</td> <td>600</td> <td>600</td> <td>400</td> <td>300</td> <td>200</td> </tr> </table> <p data-bbox="890 751 1516 1407"> 2. The maximum installation height above ground level must not be more than 7 metres. 3. The product is only to be installed on timber and steel framework. 4. The fastenings must be in accordance with the following – <table border="1" data-bbox="914 884 1475 1087"> <thead> <tr> <th>Fasteners</th> <th>75mm Panels</th> <th>40mm Panels</th> </tr> </thead> <tbody> <tr> <td>Screw</td> <td>10g x 100mm CSK Head coarse ribbed Class 3</td> <td>10g x 75mm CSK Head coarse ribbed Class 3</td> </tr> <tr> <td>Washer</td> <td>Insulcon approved plastic washers</td> <td></td> </tr> </tbody> </table> </p> <p data-bbox="890 1108 1516 1407"> 5. All fastenings must be protected against corrosion as set out in Table 3.3.3.1 of the Building Code of Australia Volume 2 , as published from time to time. 6. All fixtures and features attached to the wall must be secured into the wall framing. 7. The product must only be used with breathable sarking behind the panels. 8. Render of the panels must be applied strictly in accordance with the render manufacturer’s installation requirements. A minimum thickness of 5mm of render per coat must be applied to the external surface, with a minimum of 2 coats. </p> <p data-bbox="890 1438 1516 1486">This accreditation does not apply to any other provisions of the National Construction Code Series.</p>	450	Within 1200 of building edge	300	400	300	200	150	Elsewhere	600	600	600	400	250	600	Within 1200 of building edge	400	400	250	NS	NS	Elsewhere	600	600	400	300	200	Fasteners	75mm Panels	40mm Panels	Screw	10g x 100mm CSK Head coarse ribbed Class 3	10g x 75mm CSK Head coarse ribbed Class 3	Washer	Insulcon approved plastic washers							references to regulations	
450	Within 1200 of building edge	300	400	300		200	150																																							
	Elsewhere	600	600	600	400	250																																								
600	Within 1200 of building edge	400	400	250	NS	NS																																								
	Elsewhere	600	600	400	300	200																																								
Fasteners	75mm Panels	40mm Panels																																												
Screw	10g x 100mm CSK Head coarse ribbed Class 3	10g x 75mm CSK Head coarse ribbed Class 3																																												
Washer	Insulcon approved plastic washers																																													
Unitex Base Board System - Non-Cavity	Cladding	For use as a wall cladding system on Class 2 to 9 buildings of Type 'C' construction only and Class 1 and 10 buildings.	Accredited against Volume One BP1.1, BP1.2, FP1.4 and Volume Two P2.1, P2.2.2 of the <i>National Construction Code Series</i> as adopted by the <i>Building Regulations 2006</i> , to the extent that those clauses refer to the structural stability, resistance to wind action and rainwater action and weatherproofing of the system, subject to the following conditions:	<p data-bbox="890 1507 1516 1942"> 1. The system must be installed with stud spacings at a maximum of 600mm centres and in accordance with the 'Unitex Technical Manual - Unitex Base Board System - non cavity' dated 5 April 2011. 2. The maximum height of panelled wall must not be more than 8.5 metres above the ground level. 3. The product is only to be installed on timber and steel framework. 4. All fastenings must be protected against corrosion as set out in Table 3.3.3.1 of the Building Code of Australia Volume Two of the National Construction Code Series, as published from time to time. 5. All fixtures and architectural features attached to the wall must be secured into the wall framing. 6. The product must only be used with breathable sarking behind the panels. </p>	Unitex 22 Park Drive DANDENONG VIC 3175	V11/03-A1	01/07/2019			01/07/2019 •Certificate reissued on BRAC letterhead and signed by Chair •Certificate updated with references to regulations																																				

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation																																						
				7. Render of the panels must be applied strictly in accordance with the 'Unitex Technical Manual - Unitex Base Board System - non cavity' dated 5 April 2011. This accreditation does not apply to any other provisions of the National Construction Code Series.																																													
Wildfire Safety Bunker	Private bushfire shelter	Suitable for use by up to 12 people for a maximum period of one hour as a Class 10c building associated with a Class 1 building	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the building act 1993 has examined the application and determined that the Wildfire Safety Bunker complies with the following Performance Requirements: P2.1.1 and P2.7.6 of the National Construction Code Series, Volume Two, Building Code of Australia, Class 1 and Class 10 buildings as adopted by the Building Regulations as in force from time to time, subject to the following conditions:	(i) The Wildfire Safety Bunker twelve-person private bushfire shelter is limited to construction on sites that have been assessed as BAL-FZ or a lower BAL when assessed in accordance with AS3959 - 2018. (ii) The Wildfire Safety Bunker twelve-person private bushfire shelter is installed, operated and maintained in accordance with the Wildfire Safety Bunker Product Manual, Edition 2 - 12-person bunker updated 24 May 2011. This accreditation does not apply to any other provisions of the national construction code series.	Wildfire Safety Bunker Pty Ltd PO Box 1225 MORNINGTON VIC 3931	V11/04-A3	26/02/2020			26/02/2020 •To update reference to AS3959-2018																																							
Insulcon Raw Panel External Cladding System	External panel cladding system	Suitable for use as for use as a wall cladding system on Class 2 to 9 buildings of Type 'C' construction only and Class 1 and 10 buildings.	Accredited against Volume One BP1.1, BP1.2 and Volume Two P2.1, P2.2.2 of the <i>National Construction Code Series 2011</i> , as adopted by the <i>Building Regulations 2006</i> , to the extent that those Clauses refer to the structural stability, resistance to wind action and rainwater action, and weatherproofing of the system, subject to the following conditions:	1. The system must be installed on framing with stud spacings at a maximum of 600mm centres and in accordance with the Insulcon Panels Installation Manual issued June 2008 (revised June 2011) except that it must not be used in areas with a wind classification of more than N5 under AS 4055 and the maximum vertical fastener spacing (mm) must be as follows – <table border="1" data-bbox="931 1247 1484 1600"> <thead> <tr> <th rowspan="2">Stud spacing (mm)</th> <th rowspan="2">Location (mm)</th> <th colspan="5">Wind classification to AS 4055</th> </tr> <tr> <th>N1</th> <th>N2</th> <th>N3</th> <th>N4</th> <th>N5</th> </tr> </thead> <tbody> <tr> <td rowspan="2">450</td> <td>Within 1200 of building edge</td> <td>300</td> <td>400</td> <td>300</td> <td>200</td> <td>150</td> </tr> <tr> <td>Elsewhere</td> <td>600</td> <td>600</td> <td>600</td> <td>400</td> <td>250</td> </tr> <tr> <td rowspan="2">600</td> <td>Within 1200 of building edge</td> <td>400</td> <td>400</td> <td>250</td> <td>NS</td> <td>NS</td> </tr> <tr> <td>Elsewhere</td> <td>600</td> <td>600</td> <td>400</td> <td>300</td> <td>200</td> </tr> </tbody> </table>	Stud spacing (mm)	Location (mm)	Wind classification to AS 4055					N1	N2	N3	N4	N5	450	Within 1200 of building edge	300	400	300	200	150	Elsewhere	600	600	600	400	250	600	Within 1200 of building edge	400	400	250	NS	NS	Elsewhere	600	600	400	300	200	Insulcon Pty Ltd 28 Mickle Street DANDENONG VIC 3175	V11/05-A1	01/07/2019			01/07/2019 •Certificate reissued on BRAC letterhead and signed by Chair •Certificate updated with references to regulations	
Stud spacing (mm)	Location (mm)	Wind classification to AS 4055																																															
		N1	N2	N3	N4	N5																																											
450	Within 1200 of building edge	300	400	300	200	150																																											
	Elsewhere	600	600	600	400	250																																											
600	Within 1200 of building edge	400	400	250	NS	NS																																											
	Elsewhere	600	600	400	300	200																																											
				2. The maximum installation height above ground level must not be more than 7 metres. 3. The product is only to be installed on timber and steel framework. 4. The fastening must be in accordance with the following- <table border="1" data-bbox="946 1793 1478 1913"> <thead> <tr> <th>Fasteners</th> <th>75mm Panels</th> <th>40mm Panels</th> </tr> </thead> <tbody> <tr> <td>Screw</td> <td>10g x 100mm CSK Head coarse ribbed Class 3</td> <td>10g x 75mm CSK Head coarse ribbed Class 3</td> </tr> </tbody> </table>	Fasteners	75mm Panels	40mm Panels	Screw	10g x 100mm CSK Head coarse ribbed Class 3	10g x 75mm CSK Head coarse ribbed Class 3																																							
Fasteners	75mm Panels	40mm Panels																																															
Screw	10g x 100mm CSK Head coarse ribbed Class 3	10g x 75mm CSK Head coarse ribbed Class 3																																															

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation										
				<table border="1" data-bbox="946 279 1478 365"> <tr> <td>Washer</td> <td>Insulcon approved plastic washers</td> </tr> </table> <p>5. All fastenings must be protected against corrosion as set out in Table 3.3.3.1 of the Building Code of Australia Volume 2, as published from time to time.</p> <p>6. All fixtures and features attached to the wall must be secured into the wall framing.</p> <p>7. The product must only be used with breathable sarking behind the panels.</p> <p>8. The render of the panels must be applied strictly in accordance with the render manufacturer's installation requirements. A maximum thickness of 5mm of render per coat must be applied to the external surface, with a minimum of 2 coats.</p> <p>This accreditation does not apply to any other provisions of the National Construction Code Series.</p>	Washer	Insulcon approved plastic washers															
Washer	Insulcon approved plastic washers																				
ALWP External Insulated Finishing System	Wall cladding system	Suitable for use in Class 1 and Class 10 buildings	<p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the building act 1993 has examined the application and determined that ALWP External Insulated Finishing System complies with Performance Requirements:</p> <p>P2.1.1 and P2.2.2 of Volume Two of the National Construction Code - Building Code of Australia as adopted by the Building Regulations 2018, to the extent that those Clauses refer to the structural stability of a cladding system with regard to resistance to wind action and rainwater action, and weatherproofing of the product, subject to the following conditions:</p>	<p>1. This accreditation is limited to -</p> <ol style="list-style-type: none"> Class 1 and 10 buildings Installation height up to a maximum of 10m Buildings built in Region A, terrain categories 1 - 3 and topographic class T1, non-cyclonic wind classes N1 – N3 as per Australian standard AS 4055 - 2006 Wind loads for housing. <p>2. The product must be installed in accordance with the ALWP™ Installation Manual (ALWP Tech Man 001 - 08 June 2012).</p> <p>3. The product must only be used with a vapour permeable sarking membrane behind the panels.</p> <p>4. The packaging of the polystyrene panels shall be stamped, or otherwise marked with a legible, permanent label stating that the system must incorporate a vapour permeable sarking membrane between the polystyrene panels and the frame. If the panels are to be sold individually and not pre-packaged, the back of each panel must be stamped, or otherwise marked with a legible, permanent label stating that the system must incorporate a vapour permeable sarking membrane between the polystyrene panels and the frame.</p> <p>5. The product is only to be installed on timber framework with a maximum stud spacing of 450mm.</p> <p>6. The fastenings must be in accordance with the following:</p> <table border="1" data-bbox="914 1423 1492 1728"> <thead> <tr> <th>Panel</th> <th>Fasteners for timber frame</th> </tr> </thead> <tbody> <tr> <td>100mm</td> <td>≥125mm 10G self-tapping galvanised Class 3 screws</td> </tr> <tr> <td>75mm</td> <td>≥100mm 10G self-tapping galvanised Class 3 screws</td> </tr> <tr> <td>50mm</td> <td>≥75mm 10G self-tapping galvanised Class 3 screws</td> </tr> <tr> <td>Washer</td> <td>48mm diameter plastic washer</td> </tr> </tbody> </table> <p>7. All fastenings must be protected against corrosion as set out in Part 4 and Appendix C of AS4773.1 Masonry in small buildings Part 1: Design, as published from time to time.</p> <p>8. All fixtures and features attached to the wall must be secured into the wall framing.</p> <p>9. Render of the panels must be as specified in the ALWP™ Installation Manual.</p>	Panel	Fasteners for timber frame	100mm	≥125mm 10G self-tapping galvanised Class 3 screws	75mm	≥100mm 10G self-tapping galvanised Class 3 screws	50mm	≥75mm 10G self-tapping galvanised Class 3 screws	Washer	48mm diameter plastic washer	Australian Lightweight Products 127 Chesterville Road MOORABBIN VIC 3189	V12/02-A1	01/07/2019			<p>01/07/2019</p> <ul style="list-style-type: none"> •Certificate reissued on BRAC letterhead and signed by Chair •Certificate updated with references to regulations 	
Panel	Fasteners for timber frame																				
100mm	≥125mm 10G self-tapping galvanised Class 3 screws																				
75mm	≥100mm 10G self-tapping galvanised Class 3 screws																				
50mm	≥75mm 10G self-tapping galvanised Class 3 screws																				
Washer	48mm diameter plastic washer																				

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation
				This accreditation does not apply to any other provisions of the National Construction Code Series.							
NuClad Exterior Insulation and Finishing System	Wall cladding system	Suitable for use in Class 1 and associated Class 10 buildings	<p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the building act 1993 has examined the application and determined that NuClad Exterior Insulation and Finishing System complies with Performance Requirements:</p> <p>P2.1.1 and P2.2.2 of Volume Two of the National Construction Code - Building Code Of Australia as adopted by the Building Regulations as in force from time to time, to the extent that those Clauses refer to the structural stability, resistance to wind action and rainwater action, and weatherproofing of the product subject to the following conditions:</p>	<ol style="list-style-type: none"> This accreditation applies in the State of Victoria and is limited to - <ol style="list-style-type: none"> Class 1 and 10 buildings; Installation height up to a maximum of 6m to the underside of eaves and 8.5m to the ridge height; Installation width of the building including verandas, excluding eaves, up to a maximum of 16m; Installation height of the building up to a maximum of five times the building width; Buildings with a maximum roof pitch of 35 degrees; and Buildings built in Region A, non-cyclonic winds classes N1 - N2 as per Australian Standard AS 4055 - 2006. Product must be installed, including rendering, in accordance with the NuCLAD EIFS Technical Manual (document number TM001, Version No. V03 revised 7 August 2019 as provided by NuCLAD). The product must only be used with the Watergate vapour permeable sarking membrane behind the panels and Aluband/ Aluminium windows sealing system. <p>This accreditation does not apply to any other provisions of the National Construction Code Series.</p>	Nutex Coatings 287 Wellington Road MULGRAVE VIC 3170	V12/04-A2	25/09/2019			25/09/2019 •Reference to amend Manual TM001 V03 dated 7 August 2019	
MultiPanel Wet Area Waterproofing System	Waterproofing system	Suitable for use in Class 1 to 10 buildings	<p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and accredited the product as complying with;</p> <p>Performance Requirement FP1.7 of Volume One of the National Construction Code Series Building Code of Australia Class 2 to Class 9 buildings, and P2.4.1 of Volume Two of the National Construction Code Series.</p> <p>Building Code of Australia Class One and Class 10 buildings, as adopted by the Building Regulations 2018 as those clauses apply within the state of Victoria to wet areas in Class 1 to 10 buildings, subject to the following conditions:</p>	<ol style="list-style-type: none"> The system must be installed in accordance with the MultiPanel Installation Guide for Waterproof Bathroom and Showerbase Kit (MultiPanel 0009_13.11.13), published by MultiPanel Pty Ltd, November 2013. The product is only to be installed on timber framework constructed in accordance with AS1684 - Residential timber-framed construction. All joints and penetrations through the MultiPanel system must be sealed in accordance with Australian Standard AS3740 - of domestic wet areas, using MultiPanel FIX30 PU sealant adhesive or FMP100 PU foaming adhesive. This certificate must be incorporated in the Multipanel Installation Guide for Waterproof Bathroom and Showerbase Kit (MultiPanel 0009_13.11.13), published by MultiPanel Pty Ltd, November 2013. 	Multipanel Pty Ltd Level 1, 110 Mt Eliza Way MT ELIZA VIC 3930	V13/02-A1	15/12/2021	15/12/2024		15/12/2021 •Accreditation granted for a period of 3-years	
FCP Sanctuary Bushfire Shelter	Bushfire shelter	Suitable for use by up to five people for a maximum period of one hour as a Class 10c building associated with a Class 1 building	<p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the building act 1993 has examined the application and accredited the FCP Sanctuary Bushfire Shelter as complying with Performance Requirements:</p>	<ol style="list-style-type: none"> The FCP Sanctuary Bushfire Shelter is limited to construction on sites that have been assessed as BAL- FZ or a lower BAL when assessed in accordance with AS3959-2018. The relevant building surveyor must approve the foundation prior to placing a footing. The system must be installed, operated and maintained in accordance with FCP instruction manual "FCP Sanctuary Bushfire Shelter Manual version 24 June 2014". The outer chamber door - 	Frankston Concrete Products 30 - 44 Miles Grove SEAFORD VIC 3198	V14/01-A2	25/09/2019			25/09/2019 •Updated references to performance requirement P2.7.6	

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation
			P2.1.1, P2.7.6 and Clause 1.0.5(b)(i) the National Construction Code Series, Volume Two, Building Code of Australia, Class 1 and Class 10 buildings as adopted by the Building Regulations as in force from time to time, subject to the following conditions:	<p>a) must be no closer than 10 metres from the boundary; and</p> <p>b) must be no closer than 10 metres or 1.5 times the height of the associated Class 1 building, whichever is the greater.</p> <p>This accreditation does not apply to any other provisions of the National Construction Code Series.</p>							
Duraclenz Touch Free Sensor Operated Basin	Automated wall mounted basin which integrates the soap dispenser, tap and hand dryer functions	Suitable for use as an accessible sanitary facility	<p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and accredited the product as complying with;</p> <p>Performance Requirement FP2.1 of Volume One of the National Construction Code Series, Building Code of Australia Class 2 to Class 9 Buildings, as adopted by the Building Regulations 2018, as this clause applies within the State of Victoria to the accessibility, in relation to circulation space required for fixtures and fittings installed within a standalone automated toilet facility, subject to the following conditions:</p>	<p>i. The system must be installed in accordance with the Exeloo self-managing public toilet series publication, published by Exeloo.</p> <p>ii. This accreditation applies to Model 01 - Titan Single Auto.</p> <p>iii. This certificate must be incorporated in the Exeloo self-managing public toilet series publication, published by Exeloo.</p> <p>This accreditation does not apply to any other provisions of the National Construction Code Series.</p>	WC Innovations 13 Horscroft Place MOORABBIN VIC 3189	V14/02-A2	20/12/2021	20/12/2024		20/12/2021 •Accreditation granted for a period of 3-years	
Poly Render Polystyrene Cladding System	Rendered polystyrene wall cladding system	Suitable for use in Class 1 and Class 10 buildings	<p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and accredited the product as complying with;</p> <p>Performance Requirement P2.1.1 of Volume Two of the National Construction Code Series, P2.2.2 of Volume Two of the National Construction Code Series and P2.2.3 of Volume Two of the National Construction Code Series</p> <p>Building Code of Australia Class 1 and Class 10 buildings as adopted by the Building Regulations 2006 as these clauses apply within the State of Victoria to wall cladding subject to the following conditions:</p>	<ol style="list-style-type: none"> This accreditation applies to Poly Render direct fixed cladding system only This product must be installed on Class 1 and 10 buildings only This product must be installed in wind classifications N1 to N4 only This product must be installed in accordance with the Poly Render Polystyrene Cladding System Technical Manual, dated 14 August 2014 This product must be installed on timber and steel framework only at a maximum stud spacing of 600mm and fastener spacing of 300mm This product must be installed with breathable sarking All fixtures and features attached to the wall must be secured into the wall framing This product must be installed a minimum of 75mm from any finished external ground surface Render must be applied strictly in accordance with manufacturer's installation requirements 	Chad Plaster & Facades Pty Ltd 1366 North Road OAKLEIGH SOUTH VIC 3167	V14/03-A1	06/12/2021	06/12/2024		06/12/2021 •Accreditation granted for a period of 3-years •Condition 4 amended to include the date of publication of the product manual •Condition 8 amended to include the word "finished"	

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation
Ultratex Grey Board EIFS Wall Cladding System	Wall cladding system	Suitable for use in Class 1 and Class 10 buildings	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and accredited the product as complying with; Performance Requirement P2.1.1 of Volume Two of the National Construction Code Series and P2.2.2 of Volume Two of the National Construction Code Series Building Code of Australia Class 1 and 10 buildings, as adopted by the Building Regulations 2018, as these clauses apply within the state of Victoria to wall cladding, subject to the following conditions:	<ol style="list-style-type: none"> This accreditation applies to the Ultratex Grey Board EIFS direct fix and cavity wall cladding systems only. This product must be installed on Class 1 and 10 buildings only. This product must be installed in wind classifications N1 to N4 only. This product must be installed in accordance with the Ultratex Grey Board EIFS Wall Cladding Systems Installation & Technical Manual version 2D dated 02 December 2014. This product must be installed on timber framework only with minimum 90mm x 35mm studs at a spacing of 600mm and fastener spacing of 300mm. This product must be installed with breathable sarking. Fasteners must be installed through polystyrene panels with a minimum of 25mm depth into timber framework. All fixtures and features attached to the wall must be secured into the wall framing. This product must be installed a minimum of 100mm from any finished external ground surface. Render must be applied strictly in accordance with manufacturers installation requirements. <p>This accreditation does not apply to any other provisions of the National Construction Code Series.</p>	Ultratex Wall Cladding & Coatings P/L 15/A Malcolm Court KEALBA VIC 3021	V15/01-A2	30/11/2021	30/11/2024		<p>30/11/2021</p> <ul style="list-style-type: none"> Accreditation granted for a period of 3-years Condition 9 amended to include the word "finished" 	
Multipanel Balcony Waterproof Substrate System	External waterproof substrate system	Suitable for use for all classes of buildings	<p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and accredited the Multipanel Balcony Waterproof Substrate System as complying with Performance Requirements:</p> <p>FP1.4 of Volume One of the National Construction Code Series, Building Code of Australia Class 2 to class 9 Buildings, and</p> <p>P2.2.2 of Volume Two of the National Construction Code Series, Building Code of Australia Class 1 and 10 buildings,</p> <p>as adopted by the Building Regulations 2006, as those clauses apply within the State of Victoria to weatherproofing in Class 1 to 10 buildings, subject to the following conditions:</p>	<ol style="list-style-type: none"> This accreditation is applicable in the State of Victoria and can be used in all classes of buildings. The product, all components and fixings of the system must be installed in accordance with the MultiPanel Waterproof Balcony Substrate Installation Guide, Version 002: dated 05.12.2014. This accreditation is limited to balconies which are graded to a perimeter drainage system located along the edge of the deck. Balconies which are graded to a waste outlet within the deck surface are not addressed by this accreditation. The MultiPanel 30mm sheet system is supported on a frame installed at 300mm maximum centres in accordance with AS 1684 for timber framing and AS 3623 for steel framing and with the appropriate details described in the MultiPanel waterproof balcony substrate installation guide. When used over a platform floor, the platform floor is installed in accordance with the manufacturer's installation instructions. The fixing adhesives and sealants are polyurethane based, approved by MultiPanel and used in accordance with the MultiPanel waterproof balcony substrate installation guide. All penetrations through the MultiPanel system are sealed in accordance with the requirements of the Installation Guide, using MultiPanel Fix 30 PU adhesive sealant and FMP100 foaming PU adhesive. Any tile adhesive used to fix tiles to the panel complies with the MultiPanel Pty Ltd brochure, third party tiling primers and adhesives on MultiPanel, dated 01.11.2014. The accredited MultiPanel system is limited to areas with a wind class of N1, N2 or N3. The wall up-stand or flashing is to be at least 70mm above the finished floor level of the balcony deck (i.e. above the tiled floor). Where a door or window sill abuts the MultiPanel wall up-stand or flashing, the sill junction is to be flashed or sealed in accordance with the manufacturer's instructions. 	MultiPanel Pty Ltd Level 1, 110 Mt Eliza Way MT ELIZA VIC 3930	V15/02	27/03/2015				
PolyClad Reinforced Polystyrene	Wall cladding system	Suitable for use for Class 1 and	The Building Regulations Advisory Committee appointed under Division 4	When installed in accordance with the POLYCLAD Product Manual Version 2.1 - 05/ 2015 including all Conditions of Product Use.	POLYCLAD Pty Ltd	V15/03	27/10/2015				

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation
Cladding System		associated Class 10 buildings	of Part 12 of the building act 1993 has examined the application and accredited PolyClad Reinforced Polystyrene Cladding System as complying with Performance Requirements: P2.1 and P2.2 of Volume Two of the National Construction Code Series - Building Code of Australia 2015 as adopted by the Building Regulations 2006, to the extent that those Clauses refer to the structural stability, resistance to wind action and rainwater action, and weatherproofing of the product,		26 - 30 Fleet Street SOMERTON VIC 3062						
IBS Bushfire Shelter	Bushfire shelter	Suitable for use by up to six people for a maximum period of one hour as a Class 10c building associated with a Class 1 building	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the building act 1993 has examined the application and accredited the IBS Bushfire Shelter as complying with Performance Requirements: P2.1.1, P2.7.6 and Clause 1.0.5(b)(i) of the National Construction Code Series, Volume Two, Building Code of Australia, Class 1 and Class 10 buildings as adopted by the Building Regulations as in force from time to time, subject to the following conditions:	<ul style="list-style-type: none"> i. the IBS Bushfires Shelter is limited to construction on sites that have been assessed as BAL-FZ or a lower BAL when assessed in accordance with AS3959- 2018. ii. The relevant building surveyor must approve the foundation prior to placing a footing. iii. The system must be installed, operated and maintained in accordance with the IBS instruction manual "Innovative Building Systems Bushfire Shelter Owner's Manual version dated 30 November 2016". iv. The outer chamber door - <ul style="list-style-type: none"> a) must be no closer than 6 metres from the boundary; and b) must be no closer than 10 metres or 1.5 times the height of the associate Class 1 building, whichever is the greater. <p>This accreditation does not apply to any other provisions of the National Construction Code Series.</p>	Innovative Building Systems PO Box 518 YARA GLEN VIC 3775	V16/01-A2	25/09/2019			25/09/2019 •Updated references to performance requirement P2.7.6	
Geelong Polystyrene Cladding System	Wall cladding system	Suitable for use on low rise residential Class 1 an associated Class 10 buildings	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and accredited the product as complying with: Performance Requirement P2.1.1, P2.2.2 and P2.2.3 of the National Construction Code Series, Volume Two, Building Code of Australia, Class 1 and Class 10 buildings as adopted by the Building Interim Regulations 2017, to the extent that those clauses refer to the structural performance of external walls, resistance to wind action and rainwater action, and weatherproofing, and	<ol style="list-style-type: none"> 1. The accreditation is limited to Class 1 and Class 10 buildings in wind classes N1 to N3, with geometric limits set out in clause 1.2, of AS 4055 - 2012 Wind Loads for housing, as amended from time to time. 2. Installation must be in accordance with the Geelong Polystyrene Cladding System for Low-Rise Residential Buildings Technical Manual June 2017 Edition. 3. The system must be installed on timber framework complying with AS 1684 Residential timber - framed construction, as amended from time to time, with studs at a maximum spacing of 600mm centre to centre. 4. The sarking to be installed as part of the system must be breathable sarking. 5. Panel to timber batten fasteners must be installed with a minimum embedment depth of 25mm. 6. All fixtures and features attached to the wall must be secured into wall framing. 7. The system must be installed at a minimum of 100mm from any finished external ground surface. 8. Render must be applied strictly in accordance with the manufacturer's installation requirements. 	Geelong Polystyrene Products P/L 4 Lewalan Street GROVEDALE VIC 3216	V17/01-A1	02/12/2021	02/12/2024		02/12/2021 •Accreditation granted for a period of 3-years •Condition 7 amended to include the word "finished"	

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation												
			damp-proofing, of external wall systems, subject to the following conditions:																				
StateWall External Wall Cladding System	External wall cladding system	Suitable for use on Class 1 and Class 10 buildings	<p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the building act 1993 has examined the application and accredited the StateWall External Wall Cladding System as complying with Performance Requirements:</p> <p>P2.1.1, P2.2.2 and P2.2.3 of the National Construction Code Series, Volume Two, Building Code of Australia, Class 1 and Class 10 buildings (BCA Volume Two) as adopted by the Building Regulations 2018 to the extent that those clauses refer to the structural performance of external walls, resistance to wind action and rainwater action, and weatherproofing, and damp-proofing, of external wall systems, subject to the following conditions:</p>	<ol style="list-style-type: none"> The accreditation is limited to Class 1 and associated Class 10 buildings in wind classes N1 to N3, with geometric limits set out in clause 1.2, of AS 4055-2012 Wind loads for housing, as amended from time to time, in particular: <ul style="list-style-type: none"> the height from ground level to the underside of eaves must not exceed 6.0m; the height from ground level to the highest point of the roof, not including chimneys, must not exceed 8.5m; the width including roofed verandas but not including eaves, must not exceed 16.0m, and the length must not exceed 5 times the width; and the roof pitch must not exceed 35°. Installation must be in accordance with the StateWall External Wall Cladding System Technical and Installation Manual, Edition 5 dated February 2022, except that project specific flashing and cavity drainage details must be to the satisfaction of the relevant building surveyor. The risk score must be 20 or less, when the sum of all risk factor scores are determined in accordance with BCA Volume Two Table V2.2.1a. The relevant part of the external wall must only include windows that comply with AS 2047 The system must be installed on timber or steel framing, complying with AS 1684.2 Residential Timber-Framed Construction – Non-cyclonic areas, or NASH Standard - Residential and Low-Rise Steel Framing Part 1 or 2, as appropriate and as amended from time to time, with studs at a maximum spacing of 600 mm centre to centre. The sarking to be installed as part of the system must be breathable sarking. Panel to timber batten fasteners must be installed with a minimum embedment depth of 25mm. All fixtures and features attached to the wall must be secured into the wall framing. The system must be installed a minimum of 75 mm from any finished external ground surface. Render must be applied strictly in accordance with the manufacturer's installation requirements. 	Allstate Polystyrene Industries 26 - 28 Elliot Road DANDENONG VIC 3175	V18/01-A3	28/03/2022	28/03/2025		<p>28/03/2022</p> <ul style="list-style-type: none"> Accreditation granted for a period of 3-years Reference to new product manual (Edition 5, February 2022) Condition 9 amended to include the word "finished" 													
ScreenAway Flame Guard LD BAL - 12.5 Mesh and ScreenAway Flame Guard HD BAL - 40 Mesh	Mesh flame guard	Suitable for use as a screen where required by AS3959-2018 to the extent that LD mesh is suitable for use in BAL - 12.5 only an HD mesh is suitable for use in BAL - 12.5 up to and including BAL- 40	<p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the building act 1993 has examined the application and accredited the ScreenAway Flame Guard LD BAL - 12.5 Mesh and ScreenAway Flame Guard HD BAL - 40 Mesh as complying with Performance Requirements:</p> <p>GP5.1 and P2.7.5 of the National Construction Code Series, Volume One and Volume Two, Building Code of Australia, as adopted by</p>	<ol style="list-style-type: none"> When used in screens attached to a building that is subject to AS3959: <ol style="list-style-type: none"> the screen frame must comply with the requirements of the relevant BAL; and be installed on the building in accordance with the requirements of AS3959 2018. The mesh details as follows shall not be altered. <table border="1" data-bbox="914 1711 1498 1942"> <thead> <tr> <th>ScreenAway</th> <th>Coated fibre thickness</th> <th>Pitch</th> <th>Mesh aperture</th> </tr> </thead> <tbody> <tr> <td>LD Bushfire mesh</td> <td>0.25mm</td> <td>1.43mm X 0.86mm</td> <td>1.14mm X 0.57mm</td> </tr> <tr> <td>HD Bushfire mesh</td> <td>0.35mm</td> <td>1.28mm X 0.86mm</td> <td>0.94mm X 0.52mm</td> </tr> </tbody> </table> 	ScreenAway	Coated fibre thickness	Pitch	Mesh aperture	LD Bushfire mesh	0.25mm	1.43mm X 0.86mm	1.14mm X 0.57mm	HD Bushfire mesh	0.35mm	1.28mm X 0.86mm	0.94mm X 0.52mm	ScreenAway Holdings Limited 1- 3 Commercial Street MARLESTON SA 5033	V19/01	18/12/2019	18/12/2022			
ScreenAway	Coated fibre thickness	Pitch	Mesh aperture																				
LD Bushfire mesh	0.25mm	1.43mm X 0.86mm	1.14mm X 0.57mm																				
HD Bushfire mesh	0.35mm	1.28mm X 0.86mm	0.94mm X 0.52mm																				

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation
			the Building Regulations as in force from time to time to the extent that those performance requirements relate to screen materials for windows and doors, subject to the following conditions:	This accreditation does not apply to any other provisions of the National Construction Code Series.							
Dintel Structural Walling System	The Dintel Structural Walling System is a permanent form work constructed from an engineered Polyvinyl Chloride (PVC) polymer and consists of a 2.6mm external / internal polymer 'face' and a 2.6mm polymer internal webbing.	The Dintel Structural Walling System is used as a load bearing reinforced concrete wall system that utilises the prefabricated and modular permanent form work described	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 as examined the application and accredited the product as complying with; Performance Requirements CP2 of the National Construction Code Series, Volume One, Building Code of Australia (BCA) as published from time to time for use where a non-combustible external wall is required in Class 2 to 9 buildings of Type A or Type B construction.	<ol style="list-style-type: none"> This accreditation does not apply to any other provisions of the National Construction Code Series and only accredits the limited and conditional use of the product to the performance requirement CP2. The Dintel PVC concrete wall system must be designed by an engineer registered in the category and class of civil engineer in accordance with Volume One of the National Construction Code as published from time to time. In the event that any other Performance Solution involving a fire performance requirement within the meaning of the Building Regulations 2018 is applied to a specific building project, the project fire safety engineer must consider whether the presence of the Dintel Construction System PVC formwork used externally will affect the assessment of the building design. In consideration of a combustible external wall, the project fire safety engineer must rely on the report titled "Project: Dintel Structural Walling System - Evidence of Suitability Report- Rev F #7147101" dated February 2020, prepared by Omnii Consulting Fire Engineers. 	Dintel Structural Walling 101 Quarry Road ERSKINE PARK NSW 2759	V20/01	10/06/2020	10/06/2023			
SHAPESHELL-RT PANELS	ShapeShell-RT is a composite modular glass fibre reinforced thermoset cladding product manufactured from a combination of glass fibre fabric, thermosetting polyester resin and proprietary fire-retardant chemical resins.	ShapeShell-RT panels are used as a cavity cladding system (rainscreen) supported on a steel frame connected to a non-combustible building fabric having an FRL of not less than -/60/60.	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and accredited the product as complying with; Performance Requirements CP2 of the National Construction Code Series, Volume One, Building Code of Australia (BCA) as published from time to time for use where a non-combustible external wall is required in Class 2 to 9 buildings of Type A or Type B construction.	<ol style="list-style-type: none"> This accreditation does not apply to any other provisions of the National Construction Code Series and only accredits the limited and conditional use of the product to the Performance Requirement CP2. In the event that any other Performance Solution involving a fire performance requirement within the meaning of the Building Regulations 2018 is applied to a specific building project, the project fire safety engineer must consider whether the presence of the ShapeShell-RT panels will affect their assessment of the building design. In consideration of a combustible external wall, the project fire safety engineer must rely on "Appraisal Report for Building Product Accreditation for the ShapeShell™ - RT Panels when used as a 'rainscreen' only " project #SKC - 468- BRAC- Shapeshell - Rainscreen_Rev6 dated 10 June 2020 prepared by skip consulting for ShapeShift Pty Ltd. Each project design is subject to the conditions on page 8 of the appraisal report SKC - 468- BRAC- Shapeshell - Rainscreen_ Rev6 dated 10 June 20200. Each project must be designed and installed by Shapeshift Design Technologies. 	Shapeshift Design Technologies Suite 107, 33 Longland Street NEWSTEAD QLD 4006	V20/02	15/06/2020	15/06/2023			
GreenClad Insulated Façade System (Exterior insulation and	The GreenClad Insulated Façade System consists of a rendered	External Wall Cladding System for use on exterior walls in Class 1 and	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the	<ol style="list-style-type: none"> Impact loading requirements for windborne debris in accordance with AS 1170.2:2011 Clause 2.5.8 are not addressed Weatherproofing is subject to windows that comply with AS 2047:2014 	Painttex Pty Ltd Unit 5, 12-14 South Link DANDENONG SOUTH	V22/01	11/01/2022	11/01/2025			

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation
finishing system)	50mm, 75mm or 100mm M-Grade Expanded Polystyrene panel directly fixed to the exterior wall frame.	10 buildings and structures.	<p>application and accredited the product as complying with;</p> <p>The performance requirements that are relevant to the building product, as determined in accordance with Part A2.1 and A5.2 of the BCA Volume Two are P2.1.1, P2.2.2, V2.2.1.</p> <p>The deemed-to-satisfy provisions relevant to the performance requirements identified are 3.0.1, 3.0.2, 3.0.3, Part 3.5.4, 3.12.1.4 (e). The R-values provided are only for the GreenClad Insulated Façade system and any additional requirements of Clause 3.12.4 must be satisfied.</p> <p>Building Code of Australia Class 1 and Class 10 buildings, as adopted by the Building Regulations 2018 as those clauses apply within the State of Victoria for use on exterior walls for use in certain residential and non-habitable buildings and structures subject to the following conditions:</p>	<ol style="list-style-type: none"> 3. Timber frame is to be constructed in accordance with AS 1684-2021 or AS 1720.1:2010 4. Cold-formed steel frame is to be constructed from minimum 0.75mm BMT, G550 steel in accordance with NASH Standard for Residential and Low-rise Steel Framing, Part 1: Design Criteria, or AS 3623:1993 (R2018) Domestic Metal Framing, or AS/NZS 4600:2018 Cold-Formed Steel Structures 5. Installation of GreenClad insulated façade system must be in accordance with the GreenClad Manual Ver 5 Dt 22-10-2020 a Technical Installation Manual. 6. Only to be installed by Painttex Pty Ltd approved and experienced applicator. 7. In all installations the minimum clearance between the underside of the panel and the adjoining surface level below must comply with the specifications in Part 3.5.4.7 of Volume 2 of the NCC 8. Compliance with all other requirements applicable to the construction of the external wall including condensation management and building sealing. 	VIC 3175						
Exsulte Thermal Façade Cladding, Non-Cavity System	Expanded polystyrene non-load bearing external wall system certified in the following configurations: • Exsulte Thermal Cladding Non-Cavity System • Exsulte Composite Thermal Façade Cladding Non-Cavity System	Suitable for use as an External Wall Cladding System for use on exterior walls in residential Class 1 and 10 buildings.	<p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and accredited the product as complying with;</p> <p>Performance requirements relevant to the building product, as determined in accordance with clause A0.7 of the Building Code of Australia (BCA) and Volume Two are P2.1.1, P2.2.2, P2.2.3, P2.6.1, P2.7.5.</p> <p>The compliance solutions relevant to the performance requirements identified are:</p> <ol style="list-style-type: none"> 1. Performance solution – V2.2.1 	<ol style="list-style-type: none"> 1. Construction shall be in strict accordance with the Exsulte Thermal Façade Cladding Non-Cavity System Specification & installation Manual Australia – 01 May 2020 and Exsulte Thermal Façade Cladding Non-Cavity System Construction Drawings Manual Australia 01 May 2020. 2. The building must satisfy the parameters of Table V2.2.1a of verification method V2.2.1 weatherproofing and must achieve a risk score of not more than 20, not be subject to an ultimate limit state wind pressure of greater than 2.5kPa and windows complying with AS 2047. 3. For buildings with designs of more than an Ultimate Limit State Wind Pressure or more than +-2.5kPa but not more than +-5.5kPa, must satisfy the parameters of Table V2.2.1a of verification method V2.2.1 weatherproofing and the design serviceability limit wind pressure is not to exceed +0.82kPa and minus 1.23kPa, calculated in accordance with AS/NZ 1170.2 Structural Design Actions Part 2: Wind Actions. Note: This is deemed to include AS 4055 Wind Classifications N1, N2, N3 and N4 only. The design serviceability limit wind pressure must be verified by an endorsed building engineer. 4. Exsulte Thermal Façade Cladding Non-Cavity Systems are not suitable for use in Cyclonic Regions. 5. In all installations, the minimum clearance between the underside of panel and the adjoining finished ground surface 	Dulux Acra-Tex 1 Jeans Street BEVERLEY SA 5009	V22/04-01	06/05/2022	06/05/2025			

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation
			<p>2. Deemed to satisfy provision – 3.01, 3.02 and 3.03 Part 3.5.4, 3.10.50 and 3.12.1.4</p> <p>BCA Class 1 and Class 10 buildings, as adopted by the Building Regulations, as those clauses apply within the State of Victoria for use on exterior walls for use in certain residential and non-habitable buildings and structures subject to the following conditions:</p>	<p>level below must comply with the specifications in Part 3.5.4.7 of Volume 2 of the National Construction Code (NCC).</p> <p>6. In all cases, it is a requirement that the Exsulite Thermal Façade Cladding Non-Cavity System incorporates either:</p> <ul style="list-style-type: none"> a) A timber frame constructed in accordance with AS 1684-2010 series, b) A cold-formed steel frame constructed in accordance with AS 3623-1993 (R2018), c) NASH Standard for Residential and Low-rise Steel Framing, Part 1: Design Criteria; d) A supporting structure compliant with other standards as applicable <p>7. It is a requirement that system installation is performed by an appropriately licensed trades person to install cladding.</p> <p>8. Not suitable for use where a Fire-Resistance Level (FRL) is required for a wall and/or boundary wall</p> <p>9. Suitable for Residential External Walls to NCC Volume Two, Class 1 and 10 buildings only with wind loads to either AS/NZS 1170.2:2011 or AS 4055-2012 “Wind loads for housing” for Wind Classifications N2, N3, N4, within the AS 4055-2012 limitations less than 8.5m in height, less than 16m in width and where the length does not exceed five times the width and roof pitch does not exceed 35 degrees, fixed to either steel or timber frames.</p> <p>10. Adjacent finished grade must slope away from the building in accordance with local building codes, typically a minimum slope of 50mm over the first metre.</p> <p>11. Do not install external cladding in areas where it may remain in contact with standing water or debris. Do not backfill.</p> <p>12. Check to ensure that the correct damp proof course has been installed to slab edge and termite treatment has been completed. Where no damp proof course has been installed by others, then the damp proof course must be installed by the Exsulite Installer prior to the wall wrap being installed.</p> <p>13. This certificate is limited to the details within this certificate, including the above compliance elements, product description, purpose or use.</p> <p>14. Other than the BCA provisions and State or Territory variation(s) listed, the remainder of the information contained in the product’s literature is outside the scope of this certification.</p> <p>15. Compliance with all other requirements applicable to the construction of the external wall including condensation management and building sealing.</p> <p>16. This accreditation is based on the referred standards currently incorporated in the NCC.</p> <p>Note. The Building Regulation Advisory Committee strongly recommends that the building surveyor should oversee the transfer of detailed maintenance instructions from the builder to the owner and/or occupier.</p>							
Exsulite Thermal Façade Cladding Systems	Expanded polystyrene non-load bearing external wall system	Suitable for use as an External Wall Cladding System for use on exterior walls in residential Class 1 and 10 buildings with a self-draining cavity for moisture management, whilst providing thermal	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and accredited the product as complying with;	<p>1. Construction is to be in accordance with the Exsulite Thermal Façade Cladding Specification and Installation Manual, Australia, 1 May 2020 and Exsulite Thermal Façade Cladding Construction Drawings Manual, Australia, 1 May 2020.</p> <p>2. The building must satisfy the parameters of Table V2.2.1a of verification method V2.2.1 weatherproofing and must achieve a risk score of not more than 20, not be subject to an ultimate limit state wind pressure of greater than 2.5kPa and windows complying with AS 2047.</p> <p>3. For buildings with designs of more than an Ultimate Limit State Wind Pressure or more than +-2.5kPa but not more than +-5.5kPa, must satisfy the parameters of Table V2.2.1a of</p>	Dulux Acra-Tex 1 Jeans Street BEVERLEY SA 5009	V22/04-02	06/05/2022	06/05/2025			

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation
		performance (R value).	<p>accordance with clause A0.7 of the Building Code of Australia (BCA) and Volume Two are P2.1.1, P2.2.2, P2.2.3, P2.6.1, P2.7.5.</p> <p>The compliance solutions relevant to the performance requirements identified are:</p> <ol style="list-style-type: none"> 1. Performance solution – V2.2.1 2. Deemed to satisfy provision – 3.01, 3.02 and 3.03 Part 3.5.4, 3.10.50 and 3.12.1.4 <p>BCA Class 1 and Class 10 buildings, as adopted by the Building Regulations, as those clauses apply within the State of Victoria for use on exterior walls for use in certain residential and non-habitable buildings and structures subject to the following conditions:</p>	<p>verification method V2.2.1 weatherproofing and the design serviceability limit wind pressure is not to exceed +0.82kPa and minus 1.23kPa, calculated in accordance with AS/NZ 1170.2 Structural Design Actions Part 2: Wind Actions. Note: This is deemed to include AS 4055 Wind Classifications N1, N2, N3 and N4 only. The design serviceability limit wind pressure must be verified by an endorsed building engineer.</p> <ol style="list-style-type: none"> 4. Exsulite Thermal Façade Cladding Systems are not suitable for use in Cyclonic Regions. 5. In all installations, the minimum clearance between the underside of panel and the adjoining finished ground surface level below must comply with the specifications in Part 3.5.4.7 of Volume 2 of the National Construction Code (NCC). 6. In all cases, it is a requirement that the Exsulite Thermal Façade Cladding Systems incorporates either: <ol style="list-style-type: none"> a) A timber frame constructed in accordance with AS 1684-2010 series, b) A cold-formed steel frame constructed in accordance with AS 3623-1993 (R2018), c) NASH Standard for Residential and Low-rise Steel Framing, Part 1: Design Criteria; d) A supporting structure compliant with other standards as applicable 7. It is a requirement that system installation is performed by an appropriately licensed trades person to install cladding. 8. Not suitable for use where a Fire-Resistance Level (FRL) is required for a wall and/or boundary wall 9. Suitable for Residential External Walls to NCC Volume Two, Class 1 and 10 buildings only with wind loads to either AS/NZS 1170.2:2011 or AS 4055-2012 "Wind loads for housing" for Wind Classifications N2, N3, N4, within the AS 4055-2012 limitations less than 8.5m in height, less than 16m in width and where the length does not exceed five times the width and roof pitch does not exceed 35 degrees, fixed to either steel or timber frames. 10. Adjacent finished grade must slope away from the building in accordance with local building codes, typically a minimum slope of 50mm over the first metre. 11. Do not install external cladding in areas where it may remain in contact with standing water or debris. Do not backfill. 12. Check to ensure that the correct damp proof course has been installed to slab edge and termite treatment has been completed. Where no damp proof course has been installed by others, then the damp proof course must be installed by the Exsulite Installer prior to the wall wrap being installed. 13. This certificate is limited to the details within this certificate, including the above compliance elements, product description, purpose or use. 14. Other than the BCA provisions and State or Territory variation(s) listed, the remainder of the information contained in the product's literature is outside the scope of this certification. 15. Compliance with all other requirements applicable to the construction of the external wall including condensation management and building sealing. 16. This accreditation is based on the referred standards currently incorporated in the NCC. <p>Note. The Building Regulation Advisory Committee strongly recommends that the building surveyor should oversee the transfer of detailed maintenance instructions from the builder to the owner and/or occupier.</p>							

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation
Ontera 'Envisions' modular carpet	Modular floor covering	Suitable for use in certain Class 9 buildings	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and determined that 'Envisions' modular carpet complies with the requirements of: Clauses CP3 and CP4 of Volume One of the Building Code of Australia 1996 as adopted by the Building Regulations 1994	As those Clauses apply to floorcoverings in a patient-care area in a Class 9a building or in the auditorium or audience seating area in a Class 9b building not protected by a sprinkler system used as a theatre or public hall, subject to the condition that the carpet must not be used in a fire isolated stairway, fire isolated passageway or a fire isolated ramp. Identification details are provided in the one (1) data sheet attached	Ontera Modular Carpets Pty Ltd 171 Briens Road NORTHMEAD NSW 2152	V00/05	15/11/2000				12/07/2021
REDSTOP uPVC Physical Termite Barrier	Termite barrier	For protection of service pipe penetrations of concrete slabs	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and determined that REDSTOP uPVC PHYSICAL TERMITE BARRIER Volume One Clause BP1.1; and Volume Two Clause P2.1 of the Building Code of Australia 1996 as adopted by the Building Regulations 1994	As those Clauses apply to protection from termites, provided each installation is in accordance with the conditions for use an identification details in the four (4) data sheets attached and subject to the following conditions: (i) the barrier must be used as part of a protection system which as a whole provides an effective barrier to attack of primary building elements by subterranean termites except those primary building elements not considered to be subject to such attack, as listed in Clauses B1.3(i)(ii) of Volume One or Clauses 3.1.3(b) of Volume Two of the Building Code of Australia 1996 ; and (ii) provision of the notice detailed in Clauses B1.3(i)(ii) of Volume One or Clauses 3.1.3.2(b) of Volume Two of the Building Code of Australia 1996; and (iii) the barrier must be firmly fixed to the pipe concerned such that any gap between the barrier and the pipe is less than 0.4mm; and (iv) after installation of the barrier, pipe sealing against entry of debris must be reinstated; and (v) concrete must be carefully placed to ensure that voids which could lead to a breach of the barrier by termites are not created beneath the barrier.	Rulehaven Pty Limited 40 Inkerman Street PARRAMATTA NSW 2150	V01/01	02/01/2001				12/07/2021
Scandinavian Chimney Element	A pumice chimney and flue product	For use internally and externally in Class 1 buildings	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and determined that Scandinavian Chimney Element complies with the requirements of: Clauses P2.3.3(a), (b) and (c)(i) of Volume Two of the Building Code of Australia 1996 as adopted by the Building Regulations 1994	When installed in accordance with the conditions for use and identification details provided in the four data sheets attached.	Berg's Productions PO Box 365 BELMONT VIC 3216	V01/03	14/08/2001				12/07/2021
Capital Development Guideline 7.4 Fire Risk Management In Supported Community-Based Houses	Guideline for fire risk management in supported community-based houses	For use in Class 3 and 9a buildings as defined in Section 4 of that Guideline	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and determined that Capital Development Guideline 7.4 Fire Risk Management In Supported Community-Based Houses	Provided each subject building complies with the requirements of Section 5 of the Guidelines and support or care-staff are on-site at all times when residents are present.	Capital Management Branch Financial and Corporate Services Victorian Government Department of Human Services	V07/01	02/03/2007				25/10/2019

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation
			complies with Performance Requirement: CP1, CP2, CP3, CP4, CP6, CP7, CP8, DP2(b), DP4, DP5, DP6, EP1.2, EP1.4, EP2.1, EP2.2, EP4.1, EP4.2 and EP4.3 of Volume One of the Building Code of Australia 2006, as adopted by the Building Regulations 2006		50 Lonsdale Street MELBOURNE VIC 3000						
Capital Development Guideline 7.7 Fire Risk Management In Community-Based Houses	Guideline for Fire Risk Management In Community-Based Houses	For use in Class 3 buildings as defined in Section 4 of that Guideline	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and determined that Capital Development Guideline 7.7 Fire Risk Management In Community-Based Houses complies with Performance Requirement: CP1, CP2, CP4, CP6, CP7, CP8, DP2(b), DP4, DP6, EP1.2, EP1.4, EP2.1, EP2.2, EP4.1, EP4.2, and EP4.3 of Volume One of the Building Code of Australia 2006 as adopted by the Building Regulations 2006	Provided each subject building complies with the requirements Section 5 of the Guideline.	Capital Management Branch Financial and Corporate Services Victorian Government Department of Human Services 50 Lonsdale Street MELBOURNE VIC 3000	V07/02	02/03/2007				25/10/2019
Roof and Wall Panel Building Systems G8-01	Modular roof and wall system	For use in Class 1 and associated Class 10 buildings	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and determined that the Roof and Wall Panel Building System G8-01 complies with the following Performance Requirements: P2.1, P2.2.2, P2.2.3 and P2.6.1 of Volume Two of the Building Code of Australia 2006 as adopted by the Building Regulations 2006 as those Clauses refer to the structural stability, weatherproofing, damp-proofing and thermal performance of the building system, and subject to the following conditions:	(i) certificate of accreditation is limited to the above four (4) performance requirements; (ii) a manufacturer's compliance plate must be affixed to the services box outlining the parameters for: (a) any future roof and wall penetrations proposed by the building owner; and (b) the maximum dead loads a panel is able to support. (iii) must be fixed to a concrete slab footing system. (iv) compliance with the attached three (3) data sheets	Ladyhill Pty Ltd PO Box 1559 GEEELONG VIC 3220	V07/04	16/05/2007				12/07/2021
Bradford Cavity Wall Insulation	Cavity wall insulation	For use in brick cavity and brick veneer construction	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and determined that Bradford Cavity Wall Insulation complies with Performance Requirements: FP 1.4 of Volume One and P2.2.2 of Volume Two of the	As those clauses apply to the insulating material being placed in the brick cavity and brick veneer construction when installed in accordance with the conditions for use and identification details provided in the two (2) data sheets attached.	CSR Bradford Insulation 159 Wellington Road CLAYTON VIC 3168	V07/05	21/11/2007				28/08/2019

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation												
			Building Code of Australia 2007, as adopted by the Building Regulations 2006																				
Winns water Saver	Water saver	For use in Class 1 buildings	<p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and determined that Winns Water Saver complies with Performance Requirement:</p> <p>P2.6.1 of Volume Two of the Building Code of Australia 2009, as adopted by the Building Regulations 2006, as that Clause applies to the efficient use of water, subject to the following conditions:</p>	<ul style="list-style-type: none"> (i) Winns Water Saver must be installed in accordance with the Winns Water Saver Installation Manual and Operating Instructions Model No. Mark 3 dated 25th October 2009. (ii) Winns Water Saver unit must be fitted to all shower, bathroom basin and kitchen sink heated water outlets. (iii) The roof holding tank must have a minimum capacity of 150L with provisions for overflow. (iv) The roof holding tank must be connected to all sanitary flushing systems. (v) If a reticulated water supply from a network utility operator is connected to the building, an automatic or manual interchange device that allows alternate use of water from the roof holding tank or the reticulated water supply must be installed to ensure that there is a continual supply of water for sanitary flushing. (vi) The sanitary flushing system must incorporate a cistern capable of operating at a minimum working pressure of not more than 20kPa or lower if specified by the cistern manufacturer. 	Winns Folly Pty Ltd 36 Edward Street MACKAY QLD 4740	V10/02	29/03/2010				12/07/2021												
RMAX Orangeboard External Polystyrene Insulated Cladding System	Wall cladding system	For use in Class 1 and associated Class 10 buildings	<p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and determined that the RMAX Orangeboard External Polystyrene Insulated Cladding System complies with Performance Requirements:</p> <p>P2.1 and P2.2.2</p> <p>of Volume Two of the Building Code of Australia 2010 as adopted by the Building Regulations 2006, to the extent that those Clauses refer to the structural stability, resistance to wind action and rainwater action, and weatherproofing of the system, subject to the following conditions:</p>	<ol style="list-style-type: none"> 1. This accreditation is limited to: <ul style="list-style-type: none"> - Class 1 and 10 buildings. - Maximum installation height above ground level of 10 metres. - Buildings built in wind terrain categories 2 to 3 as per Australian Standard AS 4055 – 2006. 2. The system must be installed in accordance with RMAX OrangeBoard Insulated Cladding System Technical Data Manual (Published June 2010). 3. The system must only be used with breathable sarking directly behind the panels. 4. The packaging of the polystyrene panels shall be stamped, or otherwise marked with a legible, permanent label stating that the system must incorporate a vapour permeable sarking membrane between the polystyrene panels and the frame. If the panels are to be sold individually and not pre-packaged, the back of each panel shall be stamped, or otherwise marked with a legible, permanent label stating that the system must incorporate a vapour permeable sarking membrane between the polystyrene panels and the frame. 5. The system is only to be installed on timber or steel framework. 6. The fastenings shall be in accordance with the following table: <table border="1" data-bbox="893 1514 1516 1745"> <thead> <tr> <th>Fasteners</th> <th>Timber frame</th> <th>Steel frame</th> </tr> </thead> <tbody> <tr> <td>Screw (100mm panel)</td> <td>10G x 125mm CSK Head coarse ribbed Class 3</td> <td>10G x 115mm Wing Tek Class 3</td> </tr> <tr> <td>Screw (75mm panel)</td> <td>10G x 100mm CSK Head coarse ribbed Class 3</td> <td>10G x 90mm Wing Tek Class 3</td> </tr> <tr> <td>Washer</td> <td colspan="2">40mm diameter plastic OrangeBoard washer</td> </tr> </tbody> </table> <ol style="list-style-type: none"> 7. All fastenings must be protected against corrosion as set out in Table 3.3.3.1 of the Building Code of Australia Volume Two. 8. All fixtures and features attached to the wall must be secured into the wall framing. 9. There must be a minimum of two coats of render. The base coat shall be 3-5mm with one layer of embedded mesh prior to the second coat being applied. The second coat of render shall be a minimum thickness of 2-3mm. A finish coat of primer/sealer 	Fasteners	Timber frame	Steel frame	Screw (100mm panel)	10G x 125mm CSK Head coarse ribbed Class 3	10G x 115mm Wing Tek Class 3	Screw (75mm panel)	10G x 100mm CSK Head coarse ribbed Class 3	10G x 90mm Wing Tek Class 3	Washer	40mm diameter plastic OrangeBoard washer		RMAX Pty Ltd 2 – 4 Mephan Street MARIBYRNONG VIC 3032	V10/03A	03/09/2010				26/06/2019
Fasteners	Timber frame	Steel frame																					
Screw (100mm panel)	10G x 125mm CSK Head coarse ribbed Class 3	10G x 115mm Wing Tek Class 3																					
Screw (75mm panel)	10G x 100mm CSK Head coarse ribbed Class 3	10G x 90mm Wing Tek Class 3																					
Washer	40mm diameter plastic OrangeBoard washer																						

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation																		
				preparation must be applied. Render must be applied to the panels in accordance with the render manufacturer's installation requirements.																									
ThermaWallPlus External Insulated Cladding	External insulated cladding system	Suitable for use in Class 1 and associated Class 10 buildings	<p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and determined that the ThermaWallPlus External Insulated Cladding complies with the following Performance Requirements:</p> <p>P2.1 and P2.2.2 of Volume Two of the Building Code of Australia 2010 as adopted by the Building Regulations 2006, to the extent that those Clauses refer to the structural stability, resistance to wind action and rainwater action, and weatherproofing of the product, subject to the following conditions:</p>	<ol style="list-style-type: none"> This accreditation is limited to - <ul style="list-style-type: none"> Class 1 and class 10 buildings. A maximum installation height above ground level of 7 metres. Buildings built in terrain categories 1 - 3 and topographic class T1 as per Australian Standard AS 4055- 2006. the product must be installed in accordance with the RMAX ThermaWallPlus Technical Manual (Version 4 dated January 2011). The product must only be used with a vapour permeable sarking membrane behind the panels. The packaging of the polystyrene panels shall be stamped, or otherwise marked with a legible, permanent label stating that the system must incorporate a vapour permeable sarking membrane between the polystyrene panels and the frame. If the panels are to be sold individually and not pre-packaged, the back of each panel must be stamped, or otherwise marked with a legible, permanent label stating that the system must incorporate a vapour permeable sarking membrane between the polystyrene panels and the frame. The product is only to be installed on timber and steel framework. The fastenings must be in accordance with the following: <table border="1" data-bbox="934 1081 1498 1543"> <thead> <tr> <th>Fasteners</th> <th>Timber frame</th> <th>Steel frame</th> </tr> </thead> <tbody> <tr> <td>Screw (40mm Panel)</td> <td>10G X 65mm CSK Head Course Ribbed Class 3</td> <td>10G X 55mm Wing TEK Class 3</td> </tr> <tr> <td>Screw (60mm Panel)</td> <td>10G X 85mm CSK Head Course Ribbed Class 3</td> <td>10G X 75mm Wing TEK Class 3</td> </tr> <tr> <td>Screw (75mm Panel)</td> <td>10G X 100mm CSK Head Course Ribbed Class 3</td> <td>10G X 90mm Wing TEK Class 3</td> </tr> <tr> <td>Screw (100mm Panel)</td> <td>10G X 125mm CSK Head Course Ribbed Class 3</td> <td>10G X 115mm Wing TEK Class 3</td> </tr> <tr> <td>Washer</td> <td colspan="2">40mm diameter plastic ThermaWallPlus washer</td> </tr> </tbody> </table> All fastenings must be protected against corrosion as set out in Table 3.3.3.1 of the Building Code of Australia Volume Two, as published from time to time. All fixtures and features attached to the wall must be secured into the wall framing. Render of the panels must be as specified by RMAX in the ThermaWallPlus Technical Manual. The render must be applied in two (2) coats strictly in accordance with the render manufacturer's installation requirements. The render must have an overall thickness of at least 5mm. 	Fasteners	Timber frame	Steel frame	Screw (40mm Panel)	10G X 65mm CSK Head Course Ribbed Class 3	10G X 55mm Wing TEK Class 3	Screw (60mm Panel)	10G X 85mm CSK Head Course Ribbed Class 3	10G X 75mm Wing TEK Class 3	Screw (75mm Panel)	10G X 100mm CSK Head Course Ribbed Class 3	10G X 90mm Wing TEK Class 3	Screw (100mm Panel)	10G X 125mm CSK Head Course Ribbed Class 3	10G X 115mm Wing TEK Class 3	Washer	40mm diameter plastic ThermaWallPlus washer		RMAX a division of Huntsman Chemical Company Australia Pty Ltd 2- 4 Mephan Street MARIBYRNONG VIC 3032	V11/01	24/01/2011				26/06/2019
Fasteners	Timber frame	Steel frame																											
Screw (40mm Panel)	10G X 65mm CSK Head Course Ribbed Class 3	10G X 55mm Wing TEK Class 3																											
Screw (60mm Panel)	10G X 85mm CSK Head Course Ribbed Class 3	10G X 75mm Wing TEK Class 3																											
Screw (75mm Panel)	10G X 100mm CSK Head Course Ribbed Class 3	10G X 90mm Wing TEK Class 3																											
Screw (100mm Panel)	10G X 125mm CSK Head Course Ribbed Class 3	10G X 115mm Wing TEK Class 3																											
Washer	40mm diameter plastic ThermaWallPlus washer																												
Ezyclad Lightweight Wall Cladding System	Wall cladding system	Suitable for use in Class 1 and 10 buildings	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the building act 1993 has examined the	<ol style="list-style-type: none"> The system must be installed on framing with stud spacing at a maximum of 600mm centres and in accordance with the Ezyclad Construction & Specification Manual issued July 2011 except that it must not be used in areas with a wind classification of more than N4 under 	Ezyclad Pty Ltd 9-11 Brooklyn Court CAMPBELLFIELD VIC 3061	V11/06	23/09/2011				12/07/2021																		

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation															
			<p>application and determined that the Ezyclad Lightweight Wall Cladding System complies with the following Performance Requirements:</p> <p>Volume 2 P2.1 and P2.2.2 of the National Construction Code Series Volume Two 2011 as adopted by the Building Regulations 2006, to the extent that those Clauses refer to the structural stability, resistance to wind action and rainwater action, and weatherproofing of the system, subject to the following conditions:</p>	<p>AS 4055 and the maximum vertical fastener spacing (mm) must be as follows -</p> <table border="1" data-bbox="943 363 1478 699"> <thead> <tr> <th>Wind Classification</th> <th>450mm stud spacing</th> <th>600mm stud spacing</th> </tr> </thead> <tbody> <tr> <td>N1</td> <td>400mm</td> <td>300mm</td> </tr> <tr> <td>N2</td> <td>400mm</td> <td>300mm</td> </tr> <tr> <td>N3</td> <td>300mm</td> <td>250mm</td> </tr> <tr> <td>N4</td> <td>200mm</td> <td>200mm</td> </tr> </tbody> </table> <ol style="list-style-type: none"> The maximum installation height above ground level must not be more than 9 metres. The product is only to be installed on timber and steel framework. The fastenings must be in accordance with Ezyclad Construction & Specification Manual. All fastenings must be a minimum class 3 coated fastener, of not less than 8 gauge in diameter. All fixtures and features attached to the wall must be secured into the wall framing. The product must only be used with breathable sarking behind the panels. Render of the panels must be applied strictly in accordance with the render manufacturer's installation requirements. A minimum thickness of 5mm of render per coat must be applied to the external surface, with a minimum of 2 coats. 	Wind Classification	450mm stud spacing	600mm stud spacing	N1	400mm	300mm	N2	400mm	300mm	N3	300mm	250mm	N4	200mm	200mm							
Wind Classification	450mm stud spacing	600mm stud spacing																								
N1	400mm	300mm																								
N2	400mm	300mm																								
N3	300mm	250mm																								
N4	200mm	200mm																								
ThermaWall External Insulated Cladding		Suitable for use in class 1 and associated Class 10 buildings			RMAX Pty Ltd 2 – 4 Mephan Street MARIBYRNONG VIC 3032	V11/07	01/12/2011				26/06/2019															
ThermaWallPlus Silver, ThermaWall Silver and ThermaSilver Board External Insulated Cladding	Wall cladding system		<p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the building act 1993 has examined the application and determined that the ThermaWallPlus Silver, ThermaWall Silver and ThermaSilver Board External Insulated Cladding complies with Performance Requirements:</p> <p>P2.1 and P2.2.2 of Volume two of the National Construction Code- Building Code of Australia 2012 as adopted by the Building Regulations 2006, to the extent that those Clauses refer to structural stability, resistance to wind action and rain water action, and weatherproofing of the</p>	<ol style="list-style-type: none"> This accreditation is limited to – <ul style="list-style-type: none"> Class 1 and Class 10 buildings. A maximum insulation height above ground level of 10 metres. Buildings built in terrain categories 1- 3 and topographic class T1 as per Australian standard AS 4055- 2006. The product must be installed in accordance with the RMAX ThermaSilver Insulated Cladding Product Range Technical Manual (05_12. Version 1.0 as provided by RMAX). The product must only be used with a vapour permeable sarking membrane behind the panels. The packaging of the polystyrene panels shall be stamped, or otherwise marked with a legible, permanent label stating that the system must incorporate a vapour permeable sarking membrane between the polystyrene panels and the frame. If the panels are to be sold individually and not pre-packaged, the back of each panel must be stamped, or otherwise marked with a legible, permanent label stating that the system must incorporate a vapour permeable sarking membrane between the polystyrene panels and the frame. The product is to only be installed on timber and steel framework. 	RMAX a division of Huntsman Chemical Company Australia Pty Ltd 2- 4 Mephan Street MARIBYRNONG VIC 3032	V12/01	06/06/2012				26/06/2019															

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation																									
			product, subject to the following conditions:	<p>6. The fastenings must be in accordance with the following:</p> <table border="1" data-bbox="905 304 1513 829"> <thead> <tr> <th colspan="5">Fasteners</th> </tr> <tr> <th></th> <th>Screw (40mm panel)</th> <th>Screw (60mm panel)</th> <th>Screw (75mm panel)</th> <th>Screw (100mm panel)</th> </tr> </thead> <tbody> <tr> <td>Timber frame</td> <td>10G X 65mm CSK Head Course Ribbed Class 3</td> <td>10G X 85mm CSK Head Course Ribbed Class 3</td> <td>10G X 100mm CSK Head Course Ribbed Class 3</td> <td>10G X 125mm CSK Head Course Ribbed Class 3</td> </tr> <tr> <td>Steel frame</td> <td>10G X 55mm Wing TEK Class 3</td> <td>10G X 75mm Wing TEK Class 3</td> <td>10G X 90mm Wing TEK Class 3</td> <td>10G X 115mm Wing TEK Class 3</td> </tr> <tr> <td>Washer</td> <td colspan="4">40mm diameter plastic RMAX washer</td> </tr> </tbody> </table> <p>7. All fastenings must be protected against corrosion as set out in Table 3.3.3.1 of the National Construction Code - Building Code of Australia Volume Two, as published from time to time.</p> <p>8. All fixtures and features attached to the wall must be secured into the wall framing.</p> <p>9. Render of the panels must be as specified by RMAX in the relevant Technical Manuals.</p>	Fasteners						Screw (40mm panel)	Screw (60mm panel)	Screw (75mm panel)	Screw (100mm panel)	Timber frame	10G X 65mm CSK Head Course Ribbed Class 3	10G X 85mm CSK Head Course Ribbed Class 3	10G X 100mm CSK Head Course Ribbed Class 3	10G X 125mm CSK Head Course Ribbed Class 3	Steel frame	10G X 55mm Wing TEK Class 3	10G X 75mm Wing TEK Class 3	10G X 90mm Wing TEK Class 3	10G X 115mm Wing TEK Class 3	Washer	40mm diameter plastic RMAX washer										
Fasteners																																				
	Screw (40mm panel)	Screw (60mm panel)	Screw (75mm panel)	Screw (100mm panel)																																
Timber frame	10G X 65mm CSK Head Course Ribbed Class 3	10G X 85mm CSK Head Course Ribbed Class 3	10G X 100mm CSK Head Course Ribbed Class 3	10G X 125mm CSK Head Course Ribbed Class 3																																
Steel frame	10G X 55mm Wing TEK Class 3	10G X 75mm Wing TEK Class 3	10G X 90mm Wing TEK Class 3	10G X 115mm Wing TEK Class 3																																
Washer	40mm diameter plastic RMAX washer																																			
Tensopanel Multipurpose Insulating Panel System	Wall cladding system	Suitable for use in Class 1 an associated Class 10 buildings	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the building act 1993 has examined the application and determined that Tensopanel Multipurpose Insulating Panel System complies with Performance Requirements: P2.1 and P2.2.2 of Volume Two of the National Construction Code- Building Code of Australia 2011 as adopted by the Building Regulations 2006, to the extent that those Clauses refer to the structural stability, resistance to wind action and rainwater action, and weatherproofing of the product , subject to the following conditions:	<p>1. This accreditation applies in the state of Victoria and is limited to –</p> <ol style="list-style-type: none"> Class 1 and Class 10 buildings Installation height up to a maximum of 10 m Buildings built in region A, terrain categories 1- 3 and topographic class T1, non-cyclonic wind glasses N1- N4 as per Australian Standard AS 4055- 2006. <p>1. The product must be installed in accordance with the Tensopanel installation guide (publication TBT9906v2.BMS230812 as provided by tensor and approved).</p> <p>2. The product is not required to be installed with a sarking membrane. If sarking membranes are to be installed, they must only be a vapour permeable sarking membrane.</p> <p>3. Control joints shall be located in accordance with the design engineer’s design and in no case shall spacing exceed 4.8m.</p> <p>4. The product is only to be installed on steel framework.</p> <p>5. The fastenings must be in accordance with the installation guide.</p> <p>6. All fastenings must be protected against corrosion as set out in Part 4 and Appendix C of AS4773.1 Masonry in small buildings Part 1: Design, as published from time to time.</p> <p>7. All fixtures and features attached to the wall must be secured into the wall framing.</p> <p>8. Render of the panels must be a specified by Tensor in the relevant installation guide.</p>	Tensor Building Technologies 660 Spencer Street MELBOURNE VIC 3000	V12/03	24/08/2012				12/07/2021																									
RendeX External Cladding System	External rendered polystyrene cladding system	Suitable for use for Class 1 and Class 10 buildings	The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the building act 1993 has examined the application and accredited the RendeX External Cladding	<p>1. The system must be installed in accordance with the RendeX Cladding System Data Technical Manual, published by Prestige Wall Systems, November 2013.</p> <p>2. All fixtures and features attached to the wall must be secured into the wall framing.</p>	Prestige Wall Systems 24 Humphries Terrace KILKENNY SA 5009	V13/01-A1	25/11/2013				12/07/2021																									

(a)(i) the name of the building product	(a)(ii) a description of the building product	(a)(iii) a description of the purpose and use of the building product	(a)(iv) any regulation in relation to which the building product is accredited	(a)(v) any condition to which the accreditation is subject	(a)(vi) the name and address of the holder of the accreditation	(a)(vii) the number of the certificate of accreditation	(a)(viii) the date of issue of the current certificate of accreditation	(a)(ix) the date of expiration of the accreditation	(a)(x) in the case of an accreditation that has been renewed, the date of renewal	(a)(xi) in the case of an accreditation that has been varied, the date and details of the variation	(b)(iv) if accreditation is revoked, the date of revocation of the accreditation
			<p>System as complying with Performance Requirements: P2.1.1(a), (b) and (c), P2.2.2 and P2.2.3 of the National Construction Code Series, Volume Two, Building Code of Australia, Class 1 and Class 10 buildings as adopted by the Building Regulations 2018 as those clauses apply within the state of Victoria to the structural performance (wind loads), waterproofing, and damp-proofing, in relation to a cladding system for external walls of Class 1 and 10 buildings, subject to the following conditions:</p>	<p>3. This certificate must be incorporated in the RendeX Cladding System Data Technical Manual, published by Prestige Wall Systems, November 2013.</p> <p>This accreditation does not apply to any other provisions of the National Construction Code Series.</p>							