

Audit

92: Natural Gas Type A Installation, Including 93: LPG Type A, 94: Other Types of Gas

Performance and Compliance Check

Level 1 and Level 2 Faults

LEVEL 1

- Are the materials used fit for their intended purpose and where required appropriately authorised?
- Have approved appliances been installed correctly?
- Is the gas supply meter/cylinder location in accordance with the standard?
- Is the appliance location in accordance with its specification?
- Is the consumer piping to all appliances sized correctly?
- Is the new consumer piping gas tight?
- Is any existing consumer piping within the allowable pressure drop?
- Have the appliance fluing requirements been met?
- Have the appliance ventilation requirements been met?
- Have all the required clearances been met?
- Where required is the oxygen depletion safety device fitted?
- Does the LPG installation have the required over-pressure protection?

LEVEL 2

- Have the appliance disconnection requirements been met?
- Where required have consumer safety labels been installed?
- Is the consumer piping correctly supported?
- Is the consumer piping installed in an approved location?
- Is the appliance regulator in an accessible location?
- Does the below ground consumer piping have the required cover?
- Has the installation/appliance been commissioned?
- Have access provisions to the appliance been provided?

Audit

92: Natural Gas Type A Installation, Including 93: LPG Type A, 94: Other Types of Gas

- Have the manufacturer's installation instructions been adhered to?
- Has the class of plumbing been indicated on the compliance certificate?
- Have any components been replaced that require a compliance certificate to be lodged for the work or that are over the prescribed combined amount?
- Where relevant, has an exemption been submitted and approved for design alterations?

REFERENCES

Does the installation comply with the minimum industry standards:

- AS/NZS 5601 parts 1 & 2: Gas installations
- AS 4575: Gas appliances – Quality of servicing
- AS 3814: Industrial and commercial gas – fired appliances
- The relevant manufacturer's Installation Instructions
- AS/NZS 1596 The Storage and Handling of LP Gas

NOTES

The standards and audit items listed on this checklist are intended as a guide only and are not an exhaustive list.

Other standards may be applicable to the installation and should be referenced as required, additionally Audit items may alter dependent on actual work conducted and final installation.

Practitioners are advised to check that they are using the most current edition of the prescribed standards at the time of installation.