

# Building

Regulations Advisory Committee

## Certificate of Accreditation

### Amendment 1

<b>Name of product:</b>	MultiPanel Wet Area Waterproofing System
<b>Product description:</b>	Waterproofing system
<b>Description of the purpose and use of the building product:</b>	Suitable for use in Class 1 to 10 buildings
<b>Regulation/s in relation to which the building product is accredited:</b>	<p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and accredited the product as complying with;</p> <p>Performance Requirement FP1.7 of Volume One of the National Construction Code Series Building Code of Australia Class 2 to Class 9 buildings, and P2.4.1 of Volume Two of the National Construction Code Series.</p> <p>Building Code of Australia Class One and Class 10 buildings, as adopted by the Building Regulations 2018 as those clauses apply within the state of Victoria to wet areas in Class 1 to 10 buildings, subject to the following conditions:</p>
<b>Conditions to which the accreditation is subject:</b>	<ol style="list-style-type: none"><li>1. The system must be installed in accordance with the MultiPanel Installation Guide for Waterproof Bathroom and Showerbase Kit (MultiPanel 0009_13.11.13), published by MultiPanel Pty Ltd, November 2013</li><li>2. The product is only to be installed on timber framework constructed in accordance with AS1684 - Residential timber-framed construction</li><li>3. All joints and penetrations through the MultiPanel system must be sealed in accordance with Australian Standard AS3740 - of domestic wet areas, using MultiPanel FIX30 PU sealant adhesive or FMP100 PU foaming adhesive</li><li>4. This certificate must be incorporated in the MultiPanel Installation Guide for Waterproof Bathroom and Showerbase Kit (MultiPanel 0009_13.11.13), published by MultiPanel Pty Ltd, November 2013</li></ol>
<b>The name, address and Australian business number of the holder of the accreditation:</b>	MultiPanel Pty Ltd Level 1, 110 Mt Eliza Way MT ELIZA VIC 3930 ABN 55 105 463 616

# Building


## Regulations Advisory Committee

**Certificate number:** V13/02-A1

**Date of issue:** 15/12/2021

Refer to the Historical Details page of this Certificate.  
This Certificate is only valid when reproduced in its entirety.

**Date of expiry of accreditation:** 15/12/2024



.....  
**Commissioner Yvonne von Hartel AM**  
**Chair, Building Regulations Advisory Committee**

### **Practitioner guidance on how to use a Certificate of accreditation**

Practitioners are reminded to consider any limitations noted in this Certificate and whether the performance of the product has been tested for all aspects of the performance that it is expected to achieve in the application it is being applied to.

# Building

## Regulations Advisory Committee

### Historical Details

Certificate number:	Description:	From:	To:
V13/02	Accreditation granted.	26 November 2013	-
V13/02-A1	Amendment to Certificate: - Accreditation granted for a period of 3 years	15 December 2021	15 December 2024